

JOB NO: (31612)
GPS: N: 37.338616°
W: -100.908748°



ONEOK
WILEY MARTENS
 1700 E. SEWARD RD.
 GUTHRIE, OK 73044
 PH: (405) 293-9777 F: (405) 293-9779

COMPANY REP.:
INSTALLATION DATE:
RECTIFIER LOCATION:

STATE: KANSAS
COUNTY: SEWARD

INSTALLED BY:
CASING TYPE:
DIAMETER:
CASING DEPTH:
NO. OF ANODES:
ANODE TYPE:
ANODE LEAD TYPE:

J. WINTERS
 SCH 40 PVC
 8"
 20'
 15
 ANOTEC
 #8 HMPWE

DIA. HOLE: 8"
DEPTH: 300'
COKE TYPE: SWS
LBS INST'D: 3750
HOLE PLUG: BENTONITE
LOG VOLT: 13.08
SOURCE: TRUCK

DEPTH FT.	DRILLERS LOG	ANODE NO.	ELECTRIC LOG		DEPTH FT.	DRILLERS LOG	ANODE NO.	ELECTRIC LOG	
			NATIVE	W/O COKE				NATIVE	W/O COKE
0	TOP SOIL				210	SAND & CLAY MIX			
10				0.0	220		9		0.6
20				0.0	230		8		0.4
30	YELLOW CLAY			0.1	240		7		0.5
40				0.0	250		6		1.0
50				0.0	260	SAND & CLAY MIX	5		1.8
60	YELLOW CLAY			0.5	270		4		1.9
70				1.6	280		3		1.0
80				1.2	290		2		0.9
90				0.2	300	SAND & CLAY MIX	1		0.1
100	SANDY GRAVEL			0.2	310				
110				0.2	320				
120				0.2	330				
130				0.2	340				
140				0.3	350				
150				0.5	360				
160	SANDY GRAVEL	15		0.3	370				
170		14		0.3	380				
180		13		0.3	390				
190		12		0.4	400				
200	SAND & CLAY MIX	11		1.7	410				
		10		1.0					