

DEEP TYPE GROUND BED DATA

Company: WILLIAMS	Job No: 03741-01	Date: 12/12/18
Location: QUINTER FACILITY	County: Sheridan	State: KANSAS
Groundbed Depth: 250' Diameter: 8"	Anodes: 10	# 8 HALAR (LL 300 ft)

Depth (feet)	Strata	Mud Log Amps	Anode Position	Before Coke Log (Amps)	After Coke Log (Amps)	Completion Detail	
0	SANDY CLAY					0' - 3' SOIL	
10	SANDY CLAY	20' of SCH 40				3' - 31' BENTONITE PLUG	
20	SANDY CLAY	10" PVC Casing					
30	FLINT	0.6				31' - 250' LORESCO RS-3	
40	FLINT	1.1					
50	CLAY	1.1					
60	CLAY	1.1	10	1.1	2.3		
70	CLAY	1.3					
80	CLAY	1.0	9	1.0	2.0		
90	CLAY	1.4					
100	CLAY	1.2	8	1.2	2.1		
110	CLAY	0.9					
120	CLAY	0.9	7	0.9	1.9		
130	CLAY	0.8					
140	CLAY	1.0	6	1.0	2.0		
150	CLAY	0.8					
160	CLAY	0.8	5	0.8	1.8		
170	CLAY	0.8					
180	CLAY	0.8	4	0.8	1.9		
190	CLAY	0.9					
200	CLAY	0.9	3	0.9	2.1		
210	CLAY	0.9					
220	CLAY	0.9	2	0.9	2.2		
230	CLAY	0.8					
240	CLAY	0.8	1	0.8	2.0		
250	CLAY	1.0					
260							
270							
280							
290							
300							
310							
320							
330							
340							
350							
360							
370							
380							
390							
400							
410							
420							
430							
440							
450							



BASS ENGINEERING COMPANY
 P. O. BOX 5609
 LONGVIEW, TX 75608
 Tel (903) 759-1633 Fax (903) 759-7504