

WATER WELL RECORD (WWC-5)

KOLAR DOC ID _____ WELL ID _____

Original Record Correction Change in Well Use

LOCATION OF WATER WELL

Latitude		Longitude		Section		Township		Range		E W	Fraction	¼	¼	¼
Datum		Elevation		County										

WATER WELL OWNER

Name	
Business	
Address	
Well location at owner's address	

WELL WATER USE

--

COMPLETION

Depth of completed well: _____ ft.
Depth(s) groundwater encountered:
(1) _____ ft.; (2) _____ ft.;
(3) _____ ft.; (4) dry well
Static water level in well: _____ ft.
measured below land surface
on (mm/dd/yy): _____
measured above land surface
on (mm/dd/yy): _____
Estimated yield: _____ gpm
Water level was: _____ ft. after _____ hours
pumping _____ gpm
Pump installed? Yes No
Water well disinfected? Yes No
Date disinfected (mm/dd/yy): _____
Aquifer, if known:

NEAREST SOURCE OF POTENTIAL CONTAMINATION

Source: _____
Distance from well: _____ Direction from well: _____
Source description: _____
Source: _____
Distance from well: _____ Direction from well: _____
Source description: _____
No potential source of contamination within 100 feet.

CONSTRUCTION

Borehole interval:	Borehole diameter:
from _____ to _____ ft.	_____ in.
from _____ to _____ ft.	_____ in.
Casing height above land surface: _____ in.	
If casing height is less than 12 in. has a variance been approved?*	Yes No
*variance not required for monitoring or environmental remediation wells	
Casing type: _____	
Blank casing interval: _____ ft. to _____ ft.	
Blank casing diameter: _____ in.	
Casing joints: _____	
Weight: _____ lbs/ft.	
Wall thickness or gauge no.: _____	
Blank casing interval: _____ ft. to _____ ft.	
Blank casing diameter: _____ in.	
Casing joints: _____	
Weight: _____ lbs/ft.	
Wall thickness or gauge no.: _____	
Grout interval: _____ ft. to _____ ft.	
Grout material: _____	
Grout interval: _____ ft. to _____ ft.	
Grout material: _____	
Screen / perforation material: _____	
Screen / perforation openings: _____	
Screen / perforation intervals:	
From _____ ft. to _____ ft.	
Slot size _____ unit _____	
From _____ ft. to _____ ft.	
Slot size _____ unit _____	
Gravel pack intervals:	
Gravel pack not used: Gravel size _____ in	
From _____ ft. to _____ ft.	
Gravel pack not used: Gravel size _____ in	
From _____ ft. to _____ ft.	

PERMIT & ID NUMBERS (AS REQUIRED)

DWR Application No.: _____
KDHE / EPA Project Code: _____
Site Name: _____
KDHE UIC Class V Form Completed: Yes No
County Permit: Yes No Permit ID: _____
Lease Name & Well #: _____
of boreholes: _____ # of dewatering wells: _____

LITHOLOGIC LOG

FROM	TO	LITHOLOGY INTERVALS

COMMENTS

--

CONTRACTOR'S OR LANDOWNERS CERTIFICATION

This water well was constructed reconstructed pursuant to the stated water well contractor's license and was completed on _____. I certify that this record is true to the best of my knowledge and belief. This water well record was completed on _____ under the business name of _____, Kansas Water Well Contractor's License No. _____ under the authority of the designated person as defined in K.A.R. 28-30-2(j) and signed and certified by the electronic signature of the designated person at its submittal: _____.

Send one copy to WATER WELL OWNER and retain one for your records. Fee of \$5.00 for each constructed well.

Form	WWC5.2 - Water Well Record
Doc ID	1665757
Well Owner	Derrick Johnson
Contractor	Kansas Water Wells, Inc.

Casing

From	To	Casing Diameter	Casing Joint	Casing Weigh	Wall Thickness or Gauge Number
0	306	5	Glued		sdr 21
326	366	5	Glued		sdr 21
386	390	5	Glued		sdr 21

Form	WWC5.2 - Water Well Record
Doc ID	1665757
Well Owner	Derrick Johnson
Contractor	Kansas Water Wells, Inc.

Lithology

From	To	Lithology Intervals
0	2	topsoil,very fine
2	23	sand,fine to coarse
23	26	clay,fine,sandy
26	224	sand & gravel,fine to coarse,clayey,light
224	244	clay
244	247	sand & gravel,medium to coarse
247	282	clay,fine to coarse,gravelly
282	289	clay,pale,yellowish
289	327	clay,fine,sandy
327	342	clay,fine,sandy,dark,tannish
342	359	clay,fine,sandy
359	386	sand,fine to coarse,clayey
386	390	clay,dark,yellowish



Kansas Water Wells inc.

Test# 2

Customer	Derrick Johnson	Date	9-9-22			
Address	1146 Rd. V 5	City/State	Lakin, Ks. 67860			
County	Kearny	Quarter	SE	Sec. 7	Township 25	Range 35
GPS Format	WGS 85	Lat.	N37.893457		Long.	-101.202823
Static Water Level	226'	Proposed Well Depth	390'			

From	Pay	To	Description of Strata
0		2	Sandy top soil
2		23	Fine-coarse sand
23		26	Fine sandy clay
26		50	Fine-coarse sand
50		57	White sandy clay
57		160	Fine-coarse sand/med.-coarse gravel/cobble stone
160		224	Layered fine sandy clay/med.-coarse gravel
224		244	Clay
244	3	247	Med.-coarse sand/small gravel
247		250	Fine sandy clay/gravel/ mixed & layered
250		256	Tan sandy clay
256		264	Grey clay (sticky)
264	1	271	Fine sandy clay/med sand/layered
271		277	Gravelly grey clay
277		282	Fine sandy clay
282		289	Yellow clay (very hard & sticky)
289		299	70% fine sand/30% clay
299	8	307	Fine-med sand
307	5	312	Fine-coarse sand/couple clay streaks (used water)
312	15	327	70% fine-coarse sand/30% clay/layered (used water)
327		342	Tan sandy clay (very hard & sticky)
342		359	Fine sandy clay/couple med. Sand streaks
359	4	363	70% fine sand/30% med sand
363	4	367	Fine sandy clay/coarse sand/layered
367	5	372	70% fine sand/10% med. Sand/20% clay
Location From Old Hole			
Bags Of High Yield		Bags Of Hole Plug	

Signature

From	Pay	To	Description of strata
372	14	386	50% fine sand/50% med. Sand
386		390	Yellow gravelly clay (very hard)
	59		Total pay
			Casing schedule
0	306	306	Plain casing (pvc)
306	20	326	Mill slot screen .020" sdr-21 (pvc)
326	40	366	Plain casing sdr21 (pvc)
366	20	386	Mill slot screen .020" sdr 17 (pvc)
386	4	390	Plain casing sdr-17 (pvc) (sump)
			Back fill schedule
0		4	Pitless adapter
4	22	26	Bentonite
26	256	282	#1 fine-#1 coarse 50/50 well gravel
282	5	287	Bentonite seal
287	103	390	#1 fine-#1 coarse 50/50 well gravel