WATER WELL RECORD (WWC-5)

Constructed

KOLAR DOC ID 1674517 WELL ID

✓ Original Record ☐ Correction ☐ Change in Well Use

LOCATION OF WATER WELL

Latitude	37.85126	Longitude	-98.03498	Section	25	Township	25	Range	7 ☐E ✓W	Fraction	SW ¼ NE ¼ NE ¼
Datum	NAD83	Elevation	1502	County	Reno						

WATER WELL OWNER

Name	Robin Elliott
Business	Copper Investments LLC
Address	9 Stadium Dr Haven Ks 67543
Well location ☐ at owner's address	17819 S Dean Rd

WELL WATER USE

Domestic Household

COMPLETION

Depth of completed well: 150 ft.

Depth(s) groundwater encountered:

(1) 113 ft.; (2) 137 ft.;

(3) _____ ft.; (4) ☐ dry well

Static water level in well: 30 ft.

✓ measured below land surface on (mm/dd/yy): 11/21/2022

☐ measured above land surface on (mm/dd/yy): _____

Estimated yield: 20 gpm

Water level was: 64 ft. after 1 hours pumping 15 gpm

Pump installed? ☐ Yes ✓ No

Water well disinfected? ✓ Yes ☐ No

Date disinfected (mm/dd/yy): 11/21/2022

Aquifer, if known:

NEAREST SOURCE OF POTENTIAL CONTAMINATION

Source: _____

Distance from well: _____ Direction from well: _____

Source description: _____

Source: _____

Distance from well: _____ Direction from well: _____

Source description: _____

✓ No potential source of contamination within 100 feet.

PERMIT & ID NUMBERS (AS REQUIRED)

DWR Application No.: _____

KDHE / EPA Project Code: _____

Site Name: _____

KDHE UIC Class V Form Completed: ☐ Yes ☐ No

County Permit: ✓ Yes ☐ No Permit ID: 2022-07

Lease Name & Well #: _____

# of boreholes: ____ # of dewatering wells: ____

CONSTRUCTION

Borehole interval:

from 0 to 22 ft.

from 22 to 150 ft.

Borehole diameter:

9.5 in.

5.875 in.

Casing height above land surface: 12 in.

If casing height is less than 12 in. has a variance been approved?* ☐ Yes ✓ No

*variance not required for monitoring or environmental remediation wells

Casing type: ThermalPlastic

Blank casing interval: 0 ft. to 22 ft.

Blank casing diameter: 6 in.

Casing joints: Glued

Weight: _____ lbs/ft.

Wall thickness or gauge no.: SDR26

Blank casing interval: _____ ft. to _____ ft.

Blank casing diameter: _____ in.

Casing joints: _____

Weight: _____ lbs/ft.

Wall thickness or gauge no.: _____

Grout interval: 2 ft. to 22 ft.

Grout material: Bentonite

Grout interval: _____ ft. to _____ ft.

Grout material: _____

Screen / perforation material: None

Screen / perforation openings: _____

Screen / perforation intervals:

From _____ ft. to _____ ft.

Slot size _____ unit _____

From _____ ft. to _____ ft.

Slot size _____ unit _____

Gravel pack intervals:

Gravel pack not used: ☐ Gravel size _____ in

From _____ ft. to _____ ft.

Gravel pack not used: ☐ Gravel size _____ in

From _____ ft. to _____ ft.

LITHOLOGIC LOG

FROM	TO	LITHOLOGY INTERVALS
0	1	topsoil,brown
1	4	silt,red
4	150	shale,unknown,red

COMMENTS

CONTRACTOR'S OR LANDOWNERS CERTIFICATION

This water well was constructed ✓ reconstructed ☐ pursuant to the stated water well contractor's license and was completed on 11/21/2022. I certify that this record is true to the best of my knowledge and belief. This water well record was completed on 02/02/2023 under the business name of Miller Drilling, Kansas Water Well Contractor's License No. 447 under the authority of the designated person as defined in K.A.R. 28-30-2(j) and signed and certified by the electronic signature of the designated person at its submittal: Ezra Miller.

Send one copy to WATER WELL OWNER and retain one for your records. Fee of $5.00 for each constructed well.

KANSAS DEPARTMENT OF HEALTH AND ENVIRONMENT

Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka KS 66612-1367

(785) 296-3565 | K.S.A. 82a-1212 | v2022c