# WATER WELL RECORD (WWC-5)

Constructed

KOLAR DOC ID 1784559 WELL ID

✓ Original Record ☐ Correction ☐ Change in Well Use

## LOCATION OF WATER WELL

| Latitude | 37.7659 | Longitude | -97.36808 | Section | 30 | Township | 26 | Range | 1 ✓E ☐W | Fraction | NE ¼ NW ¼ NW ¼ |
|---|---|---|---|---|---|---|---|---|---|---|---|
| Datum | WGS84 | Elevation | 1323 | County | Sedgwick | | | | | | |

## WATER WELL OWNER

| | |
|---|---|
| Name | John Walrod |
| Business | |
| Address | 2107 w Driftwood<br>Wichita Kans 67204 |
| Well location<br>✓ at owner's address | |

## WELL WATER USE

Domestic Lawn/Garden

## COMPLETION

Depth of completed well: 39 ft.

Depth(s) groundwater encountered:

(1) _____ ft.; (2) _____ ft.;

(3) _____ ft.; (4) ☐ dry well

Static water level in well: 9 ft.

✓ measured below land surface on (mm/dd/yy): 06/11/2024

☐ measured above land surface on (mm/dd/yy): _____

Estimated yield: _____ gpm

Water level was: _____ ft. after _____ hours pumping _____ gpm

Pump installed? ✓ Yes ☐ No

Water well disinfected? ☐ Yes ☐ No

Date disinfected (mm/dd/yy): _____

Aquifer, if known:

## NEAREST SOURCE OF POTENTIAL CONTAMINATION

Source: Watertight sewer lines

Distance from well: 80 Direction from well: N

Source description:

Source:

Distance from well: Direction from well:

Source description:

☐ No potential source of contamination within 100 feet.

## PERMIT & ID NUMBERS (AS REQUIRED)

DWR Application No.:

KDHE / EPA Project Code:

Site Name:

KDHE UIC Class V Form Completed: ☐ Yes ☐ No

County Permit: ✓ Yes ☐ No Permit ID: nw-24-0

Lease Name & Well #:

# of boreholes: ____ # of dewatering wells: ____

## CONSTRUCTION

Borehole interval: from 0 to 39 ft.; from _____ to _____ ft.

Borehole diameter: 8 in.; _____ in.

Casing height above land surface: 12 in.

If casing height is less than 12 in. has a variance been approved?* ☐ Yes ✓ No

*variance not required for monitoring or environmental remediation wells

Casing type: ThermalPlastic

Blank casing interval: 0 ft. to 29 ft.

Blank casing diameter: 5 in.

Casing joints: Glued

Weight: _____ lbs/ft.

Wall thickness or gauge no.: .214

Blank casing interval: _____ ft. to _____ ft.

Blank casing diameter: _____ in.

Casing joints:

Weight: _____ lbs/ft.

Wall thickness or gauge no.:

Grout interval: 2 ft. to 22 ft.

Grout material: Bentonite

Grout interval: _____ ft. to _____ ft.

Grout material:

Screen / perforation material: PVC

Screen / perforation openings: Continuous slot (

Screen / perforation intervals:

From 29 ft. to 39 ft.

Slot size _____ unit _____

From _____ ft. to _____ ft.

Slot size _____ unit _____

Gravel pack intervals:

Gravel pack not used: ✓ Gravel size _____ in

From _____ ft. to _____ ft.

Gravel pack not used: ☐ Gravel size _____ in

From _____ ft. to _____ ft.

## LITHOLOGIC LOG

| FROM | TO | LITHOLOGY INTERVALS |
|---|---|---|
| 0 | 6 | sand,fine |
| 6 | 13 | sand,fine to medium |
| 13 | 39 | sand,medium to coarse |
| | | |
| | | |
| | | |

## COMMENTS

## CONTRACTOR'S OR LANDOWNERS CERTIFICATION

This water well was constructed ✓ reconstructed ☐ pursuant to the stated water well contractor's license and was completed on 06/11/2024. I certify that this record is true to the best of my knowledge and belief. This water well record was completed on 06/30/2024 under the business name of Bearden Pump & Well Service, Kansas Water Well Contractor's License No. 941 under the authority of the designated person as defined in K.A.R. 28-30-2(j) and signed and certified by the electronic signature of the designated person at its submittal: Todd Gottschalk.

Send one copy to WATER WELL OWNER and retain one for your records. Fee of $5.00 for each constructed well.

**KANSAS DEPARTMENT OF HEALTH AND ENVIRONMENT**

Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka KS 66612-1367

(785) 296-3565 | K.S.A. 82a-1212 | v2022c