WATER WELL RECORD (WWC5.2)

Constructed

KOLAR DOC ID 1974246 WELL ID

LOCATION OF WATER WELL

County	Finney	Section	29	Township	26	Range	32 ☐E ☑W	Fraction	NE ¼	SW ¼	SE ¼
Latitude	37.7542	Longitude	-100.83942	Datum	NAD83	Elevation	2879				

WATER WELL LOCATION ☐ at owner's address

1385 FT WEST FROM INTERSECTION OF S CO RD 15 & E LEAR RD, NORTH INTO FIELD 1075 FT

WATER WELL OWNER

Name	JOHN KLEYSTEUBER
Business	
Address	13060 S RD 20 GARDEN CITY KS 67846

PERMIT & ID NUMBERS (AS REQUIRED)

DWR Application No.: 31805

KDHE / EPA Project Code:

Site Name:

KDHE UIC Class V Form Completed: ☐ Yes ☐ No

County/Local Permit Required? ☐ Yes ☐ No

Permit Obtained? ☐ Yes ☐ No Permit ID:

Oil/Gas Lease Name & Well #:

CONSTRUCTION

Casing: Height above land surface: 24 in.

Is casing height less than 12 inches? ☐ Yes ☑ No

Blank Casing type: Steel

1st interval: 0 ft. to 325 ft.; Diameter 16 in.
Casing Joint: : Welded Weight: lbs/ft
Wall thickness or gauge no.: .250

2nd interval: 505 ft. to 545 ft.; Diameter 16 in.
Casing Joint: : Welded Weight: lbs/ft
Wall thickness or gauge no.: .250

3rd interval: 625 ft. to 632 ft.; Diameter 16 in.
Casing Joint: : Welded Weight: lbs/ft
Wall thickness or gauge no.: .250

Screen / Perforation material: Steel

Specify if other:

Screen / Perforation openings: Wire wrapped

1st interval Attach ft. to Attach ft. Slot Size Attach Attach

2nd interval ft. to ft. Slot Size

3rd interval ft. to ft. Slot Size

WELL WATER USE

Irrigation

Additional info if required:

# of Boreholes # of Dewatering Wells

COMPLETION

Depth of completed well: 632 ft.

Depth(s) groundwater encountered: ☐ Dry Well

(1) ft.; (2) ft.; (3) ft.;

Static water level in well: 306 ft.

Date measured: 05/27/2026

Measured from: ✓ Top of Casing or ☐ Ground Surface

Measured: ☐ Above or ☑ Below Land Surface

Estimated yield: 800 gpm

Pump Test Date: Water level was:

391 ft. after 4 hours pumping 800 gpm

ft. after hours pumping gpm

Pump Information:

Pump Installed? ☐ Yes ☑ No Date:

Pump Type: Horsepower: Volts:

Drop Pipe Diameter: in. Drop Pipe Length: ft.

Water well disinfected? ✓ Yes ☐ No

Date disinfected (mm/dd/yy): 05/19/2026

CONSTRUCTION

Borehole interval:

from 0 to 632 ft.
from to ft.
from to ft..

Borehole diameter:

30 in.
in.
in.

Grout:

1st Interval: 0 ft. to 20 ft. Grout material: Bentonite
2nd Interval: 280 ft. to 300 ft. Grout material: Bentonite
3rd Interval: ft. to ft. Grout material:

Gravel pack: Not Used

1st Interval: Atta ft. to Atta ft. Gravel Size: Attach ☐
2nd Interval: ft. to ft. Gravel Size: ☐
3rd Interval: ft. to ft. Gravel Size: ☐

DESIGNATED PERSON Thomas Downey

WELL COMPLETION DATE 05/19/2026

CONTRACTOR BUSINESS NAME Downey Drilling, Inc. #748

KANSAS DEPARTMENT OF HEALTH AND ENVIRONMENT
Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka KS 66612-1367

WATER WELL RECORD (WWC-5) Constructed KOLAR DOC ID 1974246 WELL ID

LOCATION OF WATER WELL

County	Finney	Section	29	Township	26	Range	32 ☐E ☑W	Fraction	NE ¼ SW ¼ SE ¼
Latitude	37.7542	Longitude	-100.83942	Datum	NAD83	Elevation	2879		
Well Owner	JOHN KLEYSTEUBER	Well Owner Business							

NEAREST SOURCE OF POTENTIAL CONTAMINATION or ✓ No potential source of contamination within 100 ft.

Source:	Source:
Distance from well (ft): Direction from well:	Distance from well (ft): Direction from well:
Source description:	Source description:
Required information for local entity? ☐ Yes ☐ No	Required information for local entity? ☐ Yes ☐ No

LITHOLOGIC LOG **AQUIFER, if known**

FROM	TO	LITHOLOGY
Attach	Attach	Attached

COMMENTS

This water well was constructed ☐ reconstructed pursuant to the stated water well contractor's license and was completed on 05/19/2026 . I certify that this record is true to the best of my knowledge and belief. This water well rcord was completed on 08/10/2026 under the business name of Downey Drilling, Inc. #748 , KS Water Well Contractor's License No. 748 under the authority of the designated person as defined in K.A.R. 28-30-2(j) and signed and certified by the electronic signature of the designated person at its submittal: Thomas Downey . Send one copy to the water well owner and the contractor should retain one copy.

KANSAS DEPARTMENT OF HEALTH AND ENVIRONMENT
Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka KS 66612-1367

K.S.A. 82a-1212
v2024c

Form	WWC5.2 - Water Well Record
Doc ID	1974246
Well Owner	JOHN KLEYSTEUBER
Contractor	Downey Drilling, Inc. #748

Lithology

From	To	Lithology Intervals
0	10	topsoil,brown,soft
10	15	clay,silty,brown,soft
15	48	sand,fine,soft
48	75	gravel,fine,soft
75	85	gravel,fine to medium,firm
85	98	clay,sandy,brown,soft
98	110	clay,brown,soft
110	121	clay,green,soft
121	135	gravel,fine,firm
135	148	clay,sandy,brown,soft
148	168	gravel,fine,firm
168	178	clay,brown,hard
178	189	gravel,fine,firm
189	195	sand,fine,soft
195	200	gravel,fine,soft
200	215	clay,brown,soft
215	230	clay,green,hard
230	250	sand,fine to coarse,hard
250	255	gravel,fine,hard
255	305	gravel,fine,firm
305	328	clay,sandy,brown,firm
328	340	sand,fine to coarse,firm
340	348	gravel,fine,firm
348	355	sand,fine to coarse,firm

Form	WWC5.2 - Water Well Record
Doc ID	1974246
Well Owner	JOHN KLEYSTEUBER
Contractor	Downey Drilling, Inc. #748

Lithology

From	To	Lithology Intervals
355	362	clay,sandy,soft
362	370	sand,fine,soft
370	380	sand,fine to coarse,soft
380	415	clay,sandy,brown,soft
415	428	clay,brown,soft
428	440	sand,fine to coarse,soft
440	465	gravel,coarse,firm
465	482	clay,brown,firm
482	495	cobbles,coarse,firm
495	510	sandstone,unknown,blue,hard
510	550	shale,unknown,hard
550	570	sandstone,unknown,red,hard
570	595	shale,unknown,gray,hard
595	632	sandstone,unknown,hard

Form	WWC5.2 - Water Well Record
Doc ID	1974246
Well Owner	JOHN KLEYSTEUBER
Contractor	Downey Drilling, Inc. #748

Screen and Gravel

From	To	Slot Size	Slot Size Units	Gravel Pack Used	Gravel Pack From	Gravel Pack To	Gravel Size
325	385	.08	inches	Yes	20	280	#1
385	425	.1	inches	Yes	300	632	#1
425	465	.08	inches	No			
465	505	.05	inches	No			
545	585	.06	inches	No			
585	625	.05	inches	No			