WATER WELL RECORD (WWC5.2)

Constructed

KOLAR DOC ID 1981069 WELL ID

LOCATION OF WATER WELL

County	Butler	Section	31	Township	28	Range	3 ✓E ☐W	Fraction	NW ¼ SE ¼ SE ¼
Latitude	37.564922	Longitude	-97.13757	Datum	WGS84	Elevation	1330		

WATER WELL LOCATION

☑ at owner's address

WATER WELL OWNER

Name	JIM SHORES
Business	JIM SHORES
Address	490 N DAWN ST ROSE HILL KS 67133

PERMIT & ID NUMBERS (AS REQUIRED)

DWR Application No.:

KDHE / EPA Project Code:

Site Name:

KDHE UIC Class V Form Completed: ☐ Yes ☐ No

County/Local Permit Required? ☐ Yes ☐ No

Permit Obtained? ☐ Yes ☑ No Permit ID:

Oil/Gas Lease Name & Well #:

CONSTRUCTION

Casing: Height above land surface: 16 in.

Is casing height less than 12 inches? ☐ Yes ☑ No

Blank Casing type: ThermalPlastic

1st interval: 0 ft. to 75 ft.; Diameter 5 in.

Casing Joint: : Glued Weight: 160 lbs/ft

Wall thickness or gauge no.: 26

2nd interval: ft. to ft.; Diameter in.

Casing Joint: : Weight: lbs/ft

Wall thickness or gauge no.:

3rd interval: ft. to ft.; Diameter in.

Casing Joint: : Weight: lbs/ft

Wall thickness or gauge no.:

Screen / Perforation material: PVC

Specify if other:

Screen / Perforation openings: Mill slot

1st interval 75 ft. to 95 ft. Slot Size .025 mils

2nd interval ft. to ft. Slot Size

3rd interval ft. to ft. Slot Size

WELL WATER USE

Domestic Lawn/Garden

Additional info if required:

# of Boreholes # of Dewatering Wells

COMPLETION

Depth of completed well: 95 ft.

Depth(s) groundwater encountered: ☐ Dry Well

(1) ft.; (2) ft.; (3) ft.;

Static water level in well: 32 ft.

Date measured: 03/31/2026

Measured from: ☐ Top of Casing or ☑ Ground Surface

Measured: ☐ Above or ☑ Below Land Surface

Estimated yield: gpm

Pump Test Date: Water level was:

ft. after hours pumping gpm

ft. after hours pumping gpm

Pump Information:

Pump Installed? ✓ Yes ☐ No Date:

Pump Type: Horsepower: Volts:

Drop Pipe Diameter: in. Drop Pipe Length: ft.

Water well disinfected? ☐ Yes ☐ No

Date disinfected (mm/dd/yy):

CONSTRUCTION

Borehole interval:

from 0 to 95 ft.

from to ft.

from to ft..

Borehole diameter:

12 in.

in.

in.

Grout:

1st Interval: 4 ft. to 24 ft. Grout material: Bentonite

2nd Interval: ft. to ft. Grout material:

3rd Interval: ft. to ft. Grout material:

Gravel pack: Not Used

1st Interval: 24 ft. to 95 ft. Gravel Size: ☐

2nd Interval: ft. to ft. Gravel Size: ☐

3rd Interval: ft. to ft. Gravel Size: ☐

DESIGNATED PERSON	Rick Chase	WELL COMPLETION DATE	03/31/2026
CONTRACTOR BUSINESS NAME	Chase Drilling		

KANSAS DEPARTMENT OF HEALTH AND ENVIRONMENT
Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka KS 66612-1367

WATER WELL RECORD (WWC-5) Constructed KOLAR DOC ID 1981069 WELL ID

LOCATION OF WATER WELL

County	Butler	Section	31	Township	28	Range	3 ☑E ☐W	Fraction	NW ¼ SE ¼ SE ¼
Latitude	37.564922	Longitude	-97.13757	Datum	WGS84	Elevation	1330		
Well Owner	JIM SHORES	Well Owner Business	JIM SHORES						

NEAREST SOURCE OF POTENTIAL CONTAMINATION or ☐ No potential source of contamination within 100 ft.

Source: Watertight sewer lines	Source:
Distance from well (ft): 31 Direction from well: E	Distance from well (ft): Direction from well:
Source description:	Source description:
Required information for local entity? ☐ Yes ☐ No	Required information for local entity? ☐ Yes ☐ No

LITHOLOGIC LOG **AQUIFER, if known**

FROM	TO	LITHOLOGY
0	3	topsoil
3	33	clay
33	95	shale,broken,red

COMMENTS

This water well was constructed ☐ reconstructed pursuant to the stated water well contractor's license and was completed on 03/31/2026. I certify that this record is true to the best of my knowledge and belief. This water well rcord was completed on 09/01/2026 under the business name of Chase Drilling, KS Water Well Contractor's License No. 611 under the authority of the designated person as defined in K.A.R. 28-30-2(j) and signed and certified by the electronic signature of the designated person at its submittal: Rick Chase. Send one copy to the water well owner and the contractor should retain one copy.