WATER WELL RECORD (WWC5.2)

Constructed

KOLAR DOC ID 1977059 WELL ID

LOCATION OF WATER WELL

County	Sherman	Section	29	Township	8	Range	39 ☐E ☑W	Fraction	NE ¼	SW ¼	NW ¼
Latitude	39.332737	Longitude	-101.704269	Datum	WGS84	Elevation	3689				

WATER WELL LOCATION

☐ at owner's address

2323 Wallnut Ave
Goodland, KS

WATER WELL OWNER

Name	Marla Harrison
Business	
Address	PO Box 624 Goodland KS 67735

PERMIT & ID NUMBERS (AS REQUIRED)

DWR Application No.:

KDHE / EPA Project Code:

Site Name:

KDHE UIC Class V Form Completed: ☐ Yes ☐ No

County/Local Permit Required? ☐ Yes ☐ No

Permit Obtained? ✓ Yes ☐ No Permit ID: 1181

Oil/Gas Lease Name & Well #:

CONSTRUCTION

Casing: Height above land surface: 24 in.

Is casing height less than 12 inches? ☐ Yes ☑ No

Blank Casing type: ThermalPlastic

1st interval: 0 ft. to 252 ft.; Diameter 5.5 in.
Casing Joint: : Glued Weight: lbs/ft
Wall thickness or gauge no.: sch 40

2nd interval: ft. to ft.; Diameter in.
Casing Joint: : Weight: lbs/ft
Wall thickness or gauge no.:

3rd interval: ft. to ft.; Diameter in.
Casing Joint: : Weight: lbs/ft
Wall thickness or gauge no.:

Screen / Perforation material: PVC

Specify if other:

Screen / Perforation openings: Saw cut

1st interval 252 ft. to 292 ft. Slot Size .016 inches

2nd interval ft. to ft. Slot Size

3rd interval ft. to ft. Slot Size

WELL WATER USE

Domestic HouseholdOther Household and Lawn/Garden

Additional info if required: Household and Lawn/Garden

# of Boreholes # of Dewatering Wells

COMPLETION

Depth of completed well: 292 ft.

Depth(s) groundwater encountered: ☐ Dry Well

(1) 223 ft.; (2) ft.; (3) ft.;

Static water level in well: 223 ft.

Date measured: 7/20/2026

Measured from: ☐ Top of Casing or ☑ Ground Surface

Measured: ☐ Above or ☑ Below Land Surface

Estimated yield: 50 gpm

Pump Test Date: Water level was:

234 ft. after 2 hours pumping 19 gpm

ft. after hours pumping gpm

Pump Information:

Pump Installed? ✓ Yes ☐ No Date: 7/22/2026

Pump Type: AC Submers Horsepower: 3 Volts: 230

Drop Pipe Diameter: 1.2 in. Drop Pipe Length: 260 ft.

Water well disinfected? ✓ Yes ☐ No

Date disinfected (mm/dd/yy): 7/20/2026

CONSTRUCTION

Borehole interval:

from 0 to 292 ft.
from to ft.
from to ft..

Borehole diameter:

9 in.
in.
in.

Grout:

1st Interval: 0 ft. to 30 ft. Grout material: Bentonite
2nd Interval: ft. to ft. Grout material:
3rd Interval: ft. to ft. Grout material:

Gravel pack: Not Used

1st Interval: 30 ft. to 292 ft. Gravel Size: 1/4 ☐
2nd Interval: ft. to ft. Gravel Size: ☐
3rd Interval: ft. to ft. Gravel Size: ☐

DESIGNATED PERSON George Kemp

WELL COMPLETION DATE 7/20/2026

CONTRACTOR BUSINESS NAME Kemp's Well Service #213

KANSAS DEPARTMENT OF HEALTH AND ENVIRONMENT
Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka KS 66612-1367

WATER WELL RECORD (WWC-5) Constructed KOLAR DOC ID 1977059 WELL ID

LOCATION OF WATER WELL

County	Sherman	Section	29	Township	8	Range	39 ☐E ☑W	Fraction	NE ¼	SW ¼	NW ¼
Latitude	39.332737	Longitude	-101.704269	Datum	WGS84	Elevation	3689				
Well Owner	Marla Harrison	Well Owner Business									

NEAREST SOURCE OF POTENTIAL CONTAMINATION or ✓ No potential source of contamination within 100 ft.

Source:	Source:
Distance from well (ft): Direction from well:	Distance from well (ft): Direction from well:
Source description:	Source description:
Required information for local entity? ☐ Yes ☐ No	Required information for local entity? ☐ Yes ☐ No

LITHOLOGIC LOG **AQUIFER, if known** Ogallala

FROM	TO	LITHOLOGY
Attach	Attach	Attached

COMMENTS

log 459 invoice 19396

This water well was constructed ☐ reconstructed pursuant to the stated water well contractor's license and was completed on 7/20/2026 . I certify that this record is true to the best of my knowledge and belief. This water well rcord was completed on 08/08/2026 under the business name of Kemp's Well Service #213 , KS Water Well Contractor's License No. 213 under the authority of the designated person as defined in K.A.R. 28-30-2(j) and signed and certified by the electronic signature of the designated person at its submittal: George Kemp . Send one copy to the water well owner and the contractor should retain one copy.

KANSAS DEPARTMENT OF HEALTH AND ENVIRONMENT
Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka KS 66612-1367

K.S.A. 82a-1212
v2024c

Form	WWC5.2 - Water Well Record
Doc ID	1977059
Well Owner	Marla Harrison
Contractor	Kemp's Well Service #213

Lithology

From	To	Lithology Intervals
41	47	caliche,moderately cemented
47	55	sand,medium,strongly cemented
55	70	sand,medium to coarse
70	78	clay,white
78	90	sand,medium to coarse,not cemented
90	103	sand,medium,strongly cemented
103	125	clay,sandy
125	140	sand,medium to coarse
140	147	sand,medium,clayey
147	218	clay,sandy,sandy clay with few strips of sand
218	246	sand,medium to coarse,moderately cemented
246	255	sand,medium to coarse,clayey
255	260	clay,sandy
260	270	sand,medium
270	271	other,hard rock
271	277	clay
277	285	sand,fine to medium
288	292	shale,unknown,black