WATER WELL RECORD (WWC5.2) Constructed KOLAR DOC ID 1981753 WELL ID

LOCATION OF WATER WELL

County	Stafford	Section	34	Township	25	Range	11 ☐E ☑W	Fraction	SE ¼ NE ¼ SE ¼
Latitude	37.82819	Longitude	-98.51002	Datum	WGS84	Elevation	1819		

WATER WELL LOCATION ☐ at owner's address

SE 130th Ave and SE 90th Street
370' west and 1315' north

WATER WELL OWNER

Name	Jared Hartman
Business	
Address	875 SE 130th Ave Turon KS 67583

PERMIT & ID NUMBERS (AS REQUIRED)

DWR Application No.:

KDHE / EPA Project Code:

Site Name:

KDHE UIC Class V Form Completed: ☐ Yes ☐ No

County/Local Permit Required? ☐ Yes ☐ No

Permit Obtained? ✓ Yes ☐ No Permit ID: WW2633

Oil/Gas Lease Name & Well #:

CONSTRUCTION

Casing: Height above land surface: 24 in.

Is casing height less than 12 inches? ☐ Yes ☑ No

Blank Casing type: ThermalPlastic

1st interval: 0 ft. to 45 ft.; Diameter 5 in.

Casing Joint: : Glued Weight: 160 lbs/ft

Wall thickness or gauge no.:

2nd interval: ft. to ft.; Diameter in.

Casing Joint: : Weight: lbs/ft

Wall thickness or gauge no.:

3rd interval: ft. to ft.; Diameter in.

Casing Joint: : Weight: lbs/ft

Wall thickness or gauge no.:

Screen / Perforation material: PVC

Specify if other:

Screen / Perforation openings: Mill slot

1st interval 45 ft. to 65 ft. Slot Size

2nd interval ft. to ft. Slot Size

3rd interval ft. to ft. Slot Size

WELL WATER USE

Domestic Household

Additional info if required:

# of Boreholes # of Dewatering Wells

COMPLETION

Depth of completed well: 65 ft.

Depth(s) groundwater encountered: ☐ Dry Well

(1) ft.; (2) ft.; (3) ft.;

Static water level in well: 27 ft.

Date measured: 08/24/2026

Measured from: ☐ Top of Casing or ☑ Ground Surface

Measured: ☐ Above or ☑ Below Land Surface

Estimated yield: 110 gpm

Pump Test Date: Water level was:

ft. after hours pumping gpm

ft. after hours pumping gpm

Pump Information:

Pump Installed? ☐ Yes ☑ No Date:

Pump Type: Horsepower: Volts:

Drop Pipe Diameter: in. Drop Pipe Length: ft.

Water well disinfected? ✓ Yes ☐ No

Date disinfected (mm/dd/yy): 08/24/2026

CONSTRUCTION

Borehole interval:

from 0 to 65 ft.

from to ft.

from to ft..

Borehole diameter:

10.6 in.

in.

in.

Grout:

1st Interval: 0 ft. to 22 ft. Grout material: Bentonite

2nd Interval: ft. to ft. Grout material:

3rd Interval: ft. to ft. Grout material:

Gravel pack: Not Used

1st Interval: 22 ft. to 65 ft. Gravel Size: ☐

2nd Interval: ft. to ft. Gravel Size: ☐

3rd Interval: ft. to ft. Gravel Size: ☐

DESIGNATED PERSON Tom Crowdis **WELL COMPLETION DATE** 08/24/2026

CONTRACTOR BUSINESS NAME Crowdis Water Well Service, Llc

KANSAS DEPARTMENT OF HEALTH AND ENVIRONMENT
Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka KS 66612-1367

WATER WELL RECORD (WWC-5) Constructed KOLAR DOC ID 1981753 WELL ID

LOCATION OF WATER WELL

County	Stafford	Section	34	Township	25	Range	11 ☐E ☑W	Fraction	SE ¼ NE ¼ SE ¼
Latitude	37.82819	Longitude	-98.51002	Datum	WGS84	Elevation	1819		
Well Owner	Jared Hartman	Well Owner Business							

NEAREST SOURCE OF POTENTIAL CONTAMINATION or ☐ No potential source of contamination within 100 ft.

Source: Septic tank	Source:
Distance from well (ft): 150 Direction from well: NE	Distance from well (ft): Direction from well:
Source description:	Source description:
Required information for local entity? ☐ Yes ☐ No	Required information for local entity? ☐ Yes ☐ No

LITHOLOGIC LOG **AQUIFER, if known**

FROM	TO	LITHOLOGY
0	4	topsoil,clayey,black
4	16	gypsum,unknown,white
16	44	sand,fine,tan
44	58	gravel,coarse
58	65	clay,tan

COMMENTS

This water well was constructed ☐ reconstructed pursuant to the stated water well contractor's license and was completed on 08/24/2026. I certify that this record is true to the best of my knowledge and belief. This water well rcord was completed on 09/05/2026 under the business name of Crowdis Water Well Service, Llc, KS Water Well Contractor's License No. 672 under the authority of the designated person as defined in K.A.R. 28-30-2(j) and signed and certified by the electronic signature of the designated person at its submittal: Tom Crowdis. Send one copy to the water well owner and the contractor should retain one copy.