WATER WELL RECORD (WWC5.2)

Constructed

KOLAR DOC ID 1979281 WELL ID

LOCATION OF WATER WELL

County	Cloud	Section	27	Township	8	Range	1 ☐E ☑W	Fraction	NW ¼ NE ¼ NE ¼
Latitude	39.334779	Longitude	-97.411478	Datum	WGS84	Elevation	1400		

WATER WELL LOCATION

☐ at owner's address

2770 Bell Rd
Miltonvale, KS 67466

WATER WELL OWNER

Name	Jody Gladbach
Business	
Address	1408 N 290th Rd Clyde KS 66938

PERMIT & ID NUMBERS (AS REQUIRED)

DWR Application No.:

KDHE / EPA Project Code:

Site Name:

KDHE UIC Class V Form Completed: ☐ Yes ☐ No

County/Local Permit Required? ☐ Yes ☐ No

Permit Obtained? ✓ Yes ☐ No Permit ID: N/A

Oil/Gas Lease Name & Well #:

CONSTRUCTION

Casing: Height above land surface: 24 in.

Is casing height less than 12 inches? ☐ Yes ☑ No

Blank Casing type: ThermalPlastic

1st interval: 0 ft. to 78 ft.; Diameter 6 in.
Casing Joint: : Glued Weight: lbs/ft
Wall thickness or gauge no.: SCH40

2nd interval: ft. to ft.; Diameter in.
Casing Joint: : Weight: lbs/ft
Wall thickness or gauge no.:

3rd interval: ft. to ft.; Diameter in.
Casing Joint: : Weight: lbs/ft
Wall thickness or gauge no.:

Screen / Perforation material: PVC

Specify if other:

Screen / Perforation openings: Mill slot

1st interval 78 ft. to 98 ft. Slot Size .032 inches

2nd interval ft. to ft. Slot Size

3rd interval ft. to ft. Slot Size

WELL WATER USE

Domestic Household

Additional info if required:

# of Boreholes # of Dewatering Wells

COMPLETION

Depth of completed well: 98 ft.

Depth(s) groundwater encountered: ☐ Dry Well

(1) 68 ft.; (2) ft.; (3) ft.;

Static water level in well: 52 ft.

Date measured: 08/11/2026

Measured from: ☐ Top of Casing or ☑ Ground Surface

Measured: ☐ Above or ☑ Below Land Surface

Estimated yield: 80 gpm

Pump Test Date: Water level was:

ft. after hours pumping gpm

ft. after hours pumping gpm

Pump Information:

Pump Installed? ✓ Yes ☐ No Date: 08/12/2026

Pump Type: AC Submers Horsepower: 1/2 Volts: 230

Drop Pipe Diameter: 1 in. Drop Pipe Length: 80 ft.

Water well disinfected? ✓ Yes ☐ No

Date disinfected (mm/dd/yy): 08/11/2026

CONSTRUCTION

Borehole interval:

from 0 to 98 ft.
from to ft.
from to ft..

Borehole diameter:

10 in.
in.
in.

Grout:

1st Interval: 0 ft. to 23 ft. Grout material: Bentonite
2nd Interval: 50 ft. to 55 ft. Grout material: Bentonite
3rd Interval: ft. to ft. Grout material:

Gravel pack: Not Used

1st Interval: 23 ft. to 50 ft. Gravel Size: ☐
2nd Interval: 55 ft. to 98 ft. Gravel Size: ☐
3rd Interval: ft. to ft. Gravel Size: ☐

DESIGNATED PERSON Kyler Erickson

WELL COMPLETION DATE 08/11/2026

CONTRACTOR BUSINESS NAME Associated Drilling, Inc. #990

KANSAS DEPARTMENT OF HEALTH AND ENVIRONMENT
Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka KS 66612-1367

WATER WELL RECORD (WWC-5) Constructed KOLAR DOC ID 1979281 WELL ID

LOCATION OF WATER WELL

County	Cloud	Section	27	Township	8	Range	1 ☐E ☑W	Fraction	NW ¼ NE ¼ NE ¼
Latitude	39.334779	Longitude	-97.411478	Datum	WGS84	Elevation	1400		
Well Owner	Jody Gladbach	Well Owner Business							

NEAREST SOURCE OF POTENTIAL CONTAMINATION or ✓ No potential source of contamination within 100 ft.

Source:	Source:
Distance from well (ft): Direction from well:	Distance from well (ft): Direction from well:
Source description:	Source description:
Required information for local entity? ☐ Yes ☐ No	Required information for local entity? ☐ Yes ☐ No

LITHOLOGIC LOG **AQUIFER, if known** Dakota

FROM	TO	LITHOLOGY
0	4	clay
4	8	shale,unweathered,red
8	30	sandstone,unweathered,yellowish
30	45	sandstone,unweathered,brown,shale lenses
45	68	sandstone,unweathered,yellowish
68	98	sandstone,moderately weathered

COMMENTS

This water well was constructed ☐ reconstructed pursuant to the stated water well contractor's license and was completed on 08/11/2026 . I certify that this record is true to the best of my knowledge and belief. This water well rcord was completed on 09/08/2026 under the business name of Associated Drilling, Inc. #990 , KS Water Well Contractor's License No. 990 under the authority of the designated person as defined in K.A.R. 28-30-2(j) and signed and certified by the electronic signature of the designated person at its submittal: Kyler Erickson . Send one copy to the water well owner and the contractor should retain one copy.

KANSAS DEPARTMENT OF HEALTH AND ENVIRONMENT
Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka KS 66612-1367

K.S.A. 82a-1212
v2024c