

WATER WELL RECORD (WWC5.2)

Constructed

KOLAR DOC ID 1983567

WELL ID _____

LOCATION OF WATER WELL

County	Ellis	Section	32	Township	13	Range	20 ☐ E ☒ W	Fraction	SW ¼	SW ¼	SE ¼
Latitude	38.871378	Longitude	-99.566361	Datum	WGS84	Elevation	2312				

WATER WELL LOCATION☐ at owner's address

North of Victoria Rd, West Ellis Ave

WATER WELL OWNER

Name	Brad Cowan
Business	Cowan
Address	471 Munjor Rd
	Ellis Ks 67637

PERMIT & ID NUMBERS (AS REQUIRED)

DWR Application No.: _____

KDHE / EPA Project Code: _____

Site Name: _____

KDHE UIC Class V Form Completed: ☐ Yes ☐ No

County/Local Permit Required? ☐ Yes ☐ No

Permit Obtained? ☒ Yes ☐ No Permit ID: n/a

Oil/Gas Lease Name & Well #: _____

CONSTRUCTION

Casing: Height above land surface: 24 in.

Is casing height less than 12 inches? ☐ Yes ☒ No

Blank Casing type: ThermalPlastic

1st interval: 0 ft. to 20 ft.; Diameter 5 in.

Casing Joint: : Glued Weight: _____ lbs/ft

Wall thickness or gauge no.: .26

2nd interval: _____ ft. to _____ ft.; Diameter _____ in.

Casing Joint: : _____ Weight: _____ lbs/ft

Wall thickness or gauge no.: _____

3rd interval: _____ ft. to _____ ft.; Diameter _____ in.

Casing Joint: : _____ Weight: _____ lbs/ft

Wall thickness or gauge no.: _____

Screen / Perforation material: PVC

Specify if other: _____

Screen / Perforation openings: Saw cut

1st interval 20 ft. to 45 ft. Slot Size _____

2nd interval _____ ft. to _____ ft. Slot Size _____

3rd interval _____ ft. to _____ ft. Slot Size _____

WELL WATER USE

Domestic Livestock/Pasture

Additional info if required:

of Boreholes

of Dewatering Wells

COMPLETION

Depth of completed well: 45 ft.

Depth(s) groundwater encountered: ☐ Dry Well

(1) _____ ft.; (2) _____ ft.; (3) _____ ft.;

Static water level in well: 25 ft.

Date measured: 09/08/2026

Measured from: ☒ Top of Casing or ☐ Ground SurfaceMeasured: ☐ Above or ☒ Below Land Surface

Estimated yield: 15 gpm

Pump Test Date: Water level was:

27 ft. after 1 hours pumping 15 gpm

_____ ft. after _____ hours pumping _____ gpm

Pump Information:Pump Installed? ☒ Yes ☐ No Date:

Pump Type: _____ Horsepower: _____ Volts:

Drop Pipe Diameter: _____ in. Drop Pipe Length: _____ ft.

Water well disinfected? ☒ Yes ☐ No

Date disinfected (mm/dd/yy): 09/08/2026

CONSTRUCTION**Borehole interval:**

from 0 to 45 ft.

from _____ to _____ ft.

from _____ to _____ ft..

Borehole diameter:

10 in.

_____ in.

_____ in.

Grout:

1st Interval: 0 ft. to 20 ft. Grout material: Bentonite

2nd Interval: _____ ft. to _____ ft. Grout material: _____

3rd Interval: _____ ft. to _____ ft. Grout material: _____

Gravel pack:

Not Used

1st Interval: 20 ft. to 45 ft. Gravel Size: _____ ☐2nd Interval: _____ ft. to _____ ft. Gravel Size: _____ ☐3rd Interval: _____ ft. to _____ ft. Gravel Size: _____ ☐**DESIGNATED PERSON** Dylan Karst**WELL COMPLETION DATE** 09/14/2026**CONTRACTOR BUSINESS NAME**

Karst Water Well Drilling and Service, Inc.

LOCATION OF WATER WELL

County	Ellis	Section	32	Township	13	Range	20	 Fraction	SW ¼	SW ¼	SE ¼
Latitude	38.871378	Longitude	-99.566361			Datum	WGS84		Elevation	2312	
Well Owner	Brad Cowan			Well Owner Business			Cowan				

NEAREST SOURCE OF POTENTIAL CONTAMINATION or ☒ No potential source of contamination within 100 ft.

Source:	Source:
Distance from well (ft): Direction from well:	Distance from well (ft): Direction from well:
Source description:	Source description:
Required information for local entity? ☐ Yes ☐ No	Required information for local entity? ☐ Yes ☐ No

LITHOLOGIC LOG

AQUIFER, if known[illegible]

COMMENTS

	water well contractor's license and was completed on 09/14/2026 . I certify that this record is true to the best of my knowledge and belief. This water well record was completed on 09/16/2026 under the business name of Karst Water Well Drilling and Service, Inc., KS Water Well Contractor's License No. 199 under the authority of the designated person as defined in K.A.R. 28-30-2(j) and signed and certified by the electronic signature of the designated person at its submittal: Dylan Karst . Send one copy to the water well owner and the contractor should retain one copy.
--	---