

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County POTT Fraction NE 1/4 SE 1/4 NE 1/4 Section number 1 Township number T 10 S Range number R 10 EW	
2. Distance and direction from nearest town or city: 3 E of Namego	
3. Owner of well: Lyle Sylvester R.R. or street: City, state, zip code: Namego 66547	
4. Locate with "X" in section below: Sketch map: <div style="display: flex; align-items: center;"> <div style="margin-right: 20px;"> <p>1 Mile</p> </div> </div>	
5. Type and color of material	
	From To
<i>top soil + clay</i>	0 14
<i>brown gravel</i>	14 26
<i>sand</i>	26 28
<i>good gravel</i>	28 32
<i>sand</i>	32 36
<i>good gravel</i>	36 41
<i>sand</i>	41 43
<i>good gravel</i>	43 48
<i>clay + shale</i>	48 54
<i>hard shale</i>	54
(Use a second sheet if needed)	
6. Bore hole dia. 30 in. Completion date 6-2-75 Well depth 49 ft.	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	9. Casing: Material AC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 34 lbs./ft. Dia. 16 in. to 49 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 3/4"
10. Screen: Manufacturer's name Johnson Type Concrete Dia. 16 Slot/gauge 1/8" Length 26 Set between 23 ft. and 49 ft. ft. and <input type="checkbox"/> ft. Gravel pack? YES Size range of material 1/4-1/8"	11. Static water level: <input type="checkbox"/> mo./day/yr. 18 ft. below land surface Date 12-22-75
12. Pumping level below land surfaces: 48 ft. after 1/2 hrs. pumping 1000 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1200 g.p.m.	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date 48
14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
16. Nearest source of possible contamination: NONE ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name WLR Model number EM HP 20 Volts 230 Length of drop pipe 47 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	19. Remarks: This report is corrected report sent in earlier grouting done
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Law Cox & Sons Inc 258 Business name Chilton, Kansas License No. Address Lawrence, Kansas Signed Lance Cox Date 6-2- Authorized representative	

T 10
 R 10
 W
 S
 E
 NE SE
 ENE
 1/4
 1/4
 1/4
 1/4