

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County POTAWATOMIE	Fraction SE 1/4 SE 1/4 SW 1/4	Section number 18	Township number T 10 S	Range number R 10 E
2. Distance and direction from nearest town or city: 1.5 SW of 2 W. - 1.75 Street address of well location if in city: Wamego				3. Owner of well: DAVE DOPORSKI R.R. or street: 1603 SUNSET City, state, zip code: WAMEGO, KANS 66547		
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 12 in. Completion date _____ Well depth 60 ft. 4-11-79	
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 29 in. RMP <input type="checkbox"/> PVC 9L Weight 5.50 lbs./ft. Dia. 8 in. to 60 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. 322		
				10. Screen: Manufacturer's name PUMPCO MPI Type PVC Dia. 8 <input checked="" type="checkbox"/> gauze .060 Length 13 Set between 97 ft. and 60 ft. ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 K 1/2		
				11. Static water level: _____ mo./day/yr. 15 ft. below land surface Date 4-11-79		
				12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 100 g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				14. Well head completion: CAP <input type="checkbox"/> Pitless adapter 24 inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 20 ft.		
				16. Nearest source of possible contamination: ft. 100 Direction W Type DRAINAGE Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		OWNER TO INSTALL SLAB				
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. STADER DRIG CO INC 182 Business name License No. Address RT 1 HOLTON, KS Signed Dale Baker Date 4-12-79 Authorized representative				

T 10 S R 10 E Sec 18

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5