WATER WELL RECORD KSA 82a-1201-1215



Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Fraction		,			Township number Range number			
T. Location of well:	Pottawatomie	tomie SW 1/4 NW. 1/4 SW 1/4					R 11	0 w	
2. Distance and direction from nearest town or city: 2. Distance and direction from nearest town or city: 3. Owner of well-Wolff Foundation R.R. or street: First Nat'l. Bank-Trust Dept. Bx.88 City, state, zip code: City, state, zip code:								Bx.88	
4. Locate with "X" in section below: Sketch map: N. Belvu N. 24						6. Bore hole dia. 30 in. Completion date 3.43.45.45. Well depth 77 ft. 3-1-77			
NW	NE X	N S	إس	d'it		7 Cable tool Rotary Hollow rod Jetted			
± W				1		8. Use:DomesticPublic supplyIndustry			
5. Type and color of material				From	То	Dia.16 in. to 38 ft. depth Wall Thickness; inches or Dia in. to ft. depth gage No			
						10. Screen: Manufacturer's name Johnson Well			
Black soil				0	2	Type Transite Dia. 16" (Slot/gauze 1/8x8 Leng 39 s Set between 38 ft. and 77 ft.			
Fine brown sand				2	21				
Med. to large brown gravel				21	38	Gravel pack?YES. Size range of material 5/8			
Fine to med. green gravel				38	41	11. Static water level: mo./day/yr. 23 ft. below land surface Date 12-27-76			
Med. to large green gravel				41	72	12. Pumping level below land surfaces: 27 ft. after 1 hrs. pumping 1000 g.p.m. 31 ft. after 3 hrs. pumping 1200 g.p.m. Estimated maximum yield 2500 g.p.m.			
Fine to med. green gravel				72	75				
Med. to large green gravel				75	77	13. Water sample submitted: mo./day/yr.			
Hard brown blay-stopped.				77		Yes X No Date 14. Well head completion:			
						Pitless adapter	Inches abov	ve grade	
						15. Well grouted? YES With: Neat cement Bentonite _X Concrete Depth: FromO ft. to1O ft.			
						16. Negrest source of possible contamination; ft. Direction <u>West</u> Type ditch			
						Well disinfected upon comple 17. Pump:	Yes Not installe		
						Manufacturer's name			
						Submersible	Turbi		
(Use a second sheet if needed)						Jet Centrifugal	Kecij		
18. Elevation: 19. Remarks: We do not install pumps. Topography: Hill Slope Upland						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hoobler Drilling Co. 323 Business name Address St. Marys, Ks. 60536			
Yalley						Signed Authorized repr	resentative Dat	3-3-77	