



USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

County WABASH		Fraction SW SW 1/4 SW 1/4		Section number 19		Township number T 10 S		Range number R 11 E	
1. Location of well: WABASH				2. Distance and direction from nearest town or city: 2 1/2 S + 3 1/2 E OF WABASH		3. Owner of well: A.C. CLAWITER R.R. or street: City, state, zip code: RR1 Bellevue, KS 66407			
4. Locate with "X" in section below: 		Sketch map: 		6. Bore hole dia. 8 in. Completion date 11-10-78 Well depth 100 ft.					
5. Type and color of material		From		To		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
Top soil		0		4		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
Clay, Brown		4		18		9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC 9L Weight 2.58 lbs./ft. Dia. 5 in. to 100 ft. depth Wall Thickness: inches or Dia. 5 in. to 100 ft. depth gage No. 1274			
Limestone, grey		18		19		10. Screen: Manufacturer's name PUMPSO MPI Type PVC Dia. 5 Slot/gauge 1020 Length 40 Set between 20 ft. and 60 ft. 20 ft. and 60 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1030x1060			
Shale, grey, Limestone, grey		19		100		11. Static water level: 18 ft. below land surface Date 11-10-78 mo./day/yr.			
						12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 10 gph ____ g.p.m.			
						13. Water sample submitted: ____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date			
						14. Well head completion: CAP <input type="checkbox"/> Pitless adapter 24 inches above grade			
						15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.			
						16. Nearest source of possible contamination: ft. 200 Direction N Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation: 1067		19. Remarks: OWNER TO INSTALL SLAB		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. STRADER DRIG CO 182 Business name License No. Address RT1 Holton, KS Signed Dale Osborn Date 11-13-78 Authorized representative					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

BR = 1049

$$\underline{\underline{V}} = 1049$$