

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County POTT	Fraction SE 1/4 SE 1/4 NE 1/4	Section number 14	Township number T 10 S R 12 EW	Range number 12 EW	
2. Distance and direction from nearest town or city: 1 1/2 E of			3. Owner of well: Bill Bunin				
Street address of well location if in city: St Marys to US-24			R.R. or street: City, state, zip code: St Marys, Kansas 66536				
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 30 in. Completion date 6-2-76 Well depth 38 ft.		
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material					9. Casing: Material AC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 34 lbs./ft. Dia. 16 in. to 38 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth 3/4"		
					10. Screen: Manufacturer's name Johnson Concrete Type Transit Dia. 16" Slot/gauge 1/8" Length 26 Set between 12 ft. and 38 ft. ft. and <input type="checkbox"/> ft. Gravel pack? YES Size range of material 1/4" - 1/8"		
					11. Static water level: <input type="checkbox"/> mo./day/yr. 6-10 ft. below land surface Date 10-15-76		
					12. Pumping level below land surfaces: 32 ft. after 1/2 hrs. pumping 900 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1050 g.p.m.		
					13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <input type="checkbox"/>		
					14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
					15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
					16. Nearest source of possible contamination: NONE ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Geo Cox & Sons Inc 258 Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address Chilton, Kansas Signed Francis Cox Date 6-2 Authorized representative		
18. Elevation:		19. Remarks: corrected report grouting done by customer					
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley							

T
R
W
S
E
S
E
N
E
10
12
14
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5