

210 511mays SW WATER WELL RECORD Form WWC-5 KSA 82a-1212

1 LOCATION OF WATER WELL Fraction Section Number Township Number Range Number
County: SHAWNEE SE 1/4 NW 1/4 SE 1/4 25 T 10 S R 12 E
Distance and direction from nearest town or city? 3/4 N 4 W Rossville Street address of well if located within city? N/A

2 WATER WELL OWNER: Gerald Pearl
RR#, St. Address, Box #: R.R. 1
City, State, ZIP Code: St. Marys, KS 66536
Board of Agriculture, Division of Water Resources
Application Number:

3 DEPTH OF COMPLETED WELL: 37 ft. Bore Hole Diameter: 8 1/2 in. to 37 ft. and in. to ft.
Well Water to be used as:
1 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 11 Injection well
2 Irrigation 4 Industrial 6 Oil field water supply 9 Dewatering 12 Other (Specify below)
7 Lawn and garden only 10 Observation well
Well's static water level: 17 ft. below land surface measured on 3 month 8 day 1981 year
Pump Test Data: Well water was 18 ft. after 2 hours pumping 20 gpm
Est. Yield gpm: Well water was 18 ft. after 2 hours pumping 40 gpm

4 TYPE OF BLANK CASING USED:
1 Steel 3 Wrought iron 5 Concrete tile Casing Joints: Glued X Clamped
2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded
Blank casing dia: 5 in. to ft., Dia in. to ft., Dia in. to ft.
Casing height above land surface: 18 in., weight lbs./ft. Wall thickness or gauge No. 214
TYPE OF SCREEN OR PERFORATION MATERIAL:
1 Steel 3 Stainless steel 5 Fiberglass 7 PVC 10 Asbestos-cement
2 Brass 4 Galvanized steel 6 Concrete tile 8 RMP (SR) 11 Other (specify)
12 None used (open hole)
Screen or Perforation Openings Are:
1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)
2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes
7 Torch cut 10 Other (specify)
Screen-Perforation Dia: in. to ft., Dia in. to ft., Dia in. to ft.
Screen-Perforated Intervals: From 20 ft. to 37 ft., From ft. to ft. to ft.
Gravel Pack Intervals: From 20 ft. to 37 ft., From ft. to ft. to ft.

5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other
Grouted Intervals: From 3 ft. to 13 ft., From ft. to ft. to ft.
What is the nearest source of possible contamination:
1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well
2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well
3 Lateral lines 6 Pit privy 9 Livestock pens 12 Insecticide storage 16 Other (specify below)
13 Watertight sewer lines
Direction from well: NORTH How many feet 75 ? Water Well Disinfected? Yes X No
Was a chemical/bacteriological sample submitted to Department? Yes No X If yes, date sample
was submitted month day year Pump Installed? Yes No X
If Yes: Pump Manufacturer's name Model No. HP Volts
Depth of Pump Intake ft. Pumps Capacity rated at gal./min.
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was
completed on March month 8 day 1981 year
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 405
This Water Well Record was completed on 3 month 12 day 1981 year under the business
name of Haworth Drilling by (signature) Walter E. Haworth

7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:
FROM TO LITHOLOGIC LOG FROM TO LITHOLOGIC LOG
0 1.5 BLK SILT
1.5 17 FINE SAND TAN
17 37 GRAY to BLUE SAND
(COURSE)
ELEVATION: 932 PM
Depth(s) Groundwater Encountered 1. 17 ft. 2. ft. 3. ft. 4. ft.
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.