


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

LS 619181 FCOR Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County SHAWNEE	Fraction NW 1/4 NW 1/4 NE 1/4	Section number 36	Township number T 10 S	Range number R 12 E
2. Distance and direction from nearest town or city: 4 W of ROSSVILLE, KANSAS		3. Owner of well: CLARENCE MEYER R.R. or street: City, state, zip code: ST. MARYS, KANSAS 66536			
4. Locate with "X" in section below: 		Sketch map: (W.H. Becker - water well - 1/2 mile)		6. Bore hole dia. 30 in. Completion date Well depth 44 ft. 4-15-75	
5. Type and color of material		From	To	7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
SAND		10	14	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
GRAVEL		14	16	9. Casing: Material AC Height: Above or below Thredded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 34 lbs./ft. Dia. 16 in. to <input type="checkbox"/> ft. depth <input type="checkbox"/> Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth <input type="checkbox"/> No.	
SAND & GRAVEL		16	20	10. Screen: Manufacturer's name JOHNSON CONCRETE Type ASBESTOS CEMENT Dia. 16 Slot/gauge 1/8" Length 26 Set between 18 ft. and 44 ft. ft. and <input type="checkbox"/> ft. Gravel pack? YES Size range of material 1/2 - 1/4"	
BLUE GRAVEL		20	36	11. Static water level: <input type="checkbox"/> mo./day/yr. 12 ft. below land surface Date 4-15-75	
GRAVEL REAL GOOD		36	46	12. Pumping level below land surfaces: 35 ft. after 1/2 hrs. pumping 1050 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1200 g.p.m.	
SHALE		46	54	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date	
STOP		54		14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
				15. Well grouted? NOTE With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <input type="checkbox"/> ft. to <input type="checkbox"/> ft.	
				16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation: 927 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		19. Remarks: WELL TO BE GROUTED BY PUMP INSTALLER ST. MARYS FARMERS UNION IMP. CO. AWARE OF REQUIREMENTS		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. GEO COX & SONS, INC 258 Business name License No. Address CLIFTON, KANSAS Signed FRANCIS LYN Date 4-15-75 Authorized representative	