

58

R

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

DAC

1. Location of well: County **Wabaunsee** Fraction **SW NE** ~~SW NE~~ **1/4-SE 1/4** Section number **16** Township number T **10S** S R **12E** E/W

2. Distance and direction from nearest town or city: **1 1/4 miles South of St. Marys, Ks.**  
Street address of well location if in city:

3. Owner of well: **Agnes Schoemann**  
R.R. or street: **c/o Joe Schoemann**  
City, state, zip code: **St. Marys, Kansas 66536**

4. Locate with "X" in section below: Sketch map:

5. Type and color of material

Type and color of material	From	To
Light brown soil	0	2
Fine brown silty sand	2	13
Small to med. brown gravel	13	21
Med. to large gray gravel	21	24
Med. gray gravel & clay	24	29
Small gray gravel & gray clay	29	31
Med. gray gravel	31	33
Med. to large gray gravel	33	42
Gray shale-stopped.	42	

6. Bore hole dia. **30** in. Completion date **3-25-77**  
Well depth **42** ft.

7.  Cable tool  Rotary  Driven  Dug  
 Hollow rod  Jetted  Bored  Reverse rotary

8. Use:  Domestic  Public supply  Industry  
 Irrigation  Air conditioning  Stock  
 Lawn  Oil field water  Other

9. Casing: Material **Trans** Height: (Above) or below  
Threaded  Welded  Surface **12** in.  
RMP  PVC  Weight \_\_\_\_\_ lbs./ft.  
Dia. **16** in. to **16** ft. depth Wall Thickness: inches or  
Dia. \_\_\_\_\_ in. to \_\_\_\_\_ ft. depth Gage No. **75"**

10. Screen: Manufacturer's name **Johnson Well Co.**  
Type **Transite** Dia. **16"**  
(Slot) gauge **1/8 x 8** Length **26'**  
Set between **16** ft. and **42** ft.  
Gravel pack? **yes** Size range of material **1/8-1/4"**

11. Static water level: \_\_\_\_\_ mo./day/yr.  
**19** ft. below land surface Date **3-25-77**

12. Pumping level below land surfaces:  
**29** ft. after **1** hrs. pumping **800** g.p.m.  
**35** ft. after **3** hrs. pumping **1000** g.p.m.  
Estimated maximum yield **1000** g.p.m.

13. Water sample submitted: \_\_\_\_\_ mo./day/yr.  
 Yes  No Date \_\_\_\_\_

14. Well head completion: \_\_\_\_\_ Pitless adapter \_\_\_\_\_ Inches above grade

15. Well grouted? **yes**  
With:  Neat cement  Bentonite  Concrete  
Depth: From **0** ft. to **10** ft.

16. Nearest source of possible contamination:  
ft. **300** Direction **east** Type **low swale**  
Well disinfected upon completion?  Yes  No

17. Pump:  Not installed  
Manufacturer's name \_\_\_\_\_  
Model number \_\_\_\_\_ HP \_\_\_\_\_ Volts \_\_\_\_\_  
Length of drop pipe \_\_\_\_\_ ft. capacity \_\_\_\_\_ g.p.m.  
Type: \_\_\_\_\_  
 Submersible  Turbine  
 Jet  Reciprocating  
 Centrifugal  Other

18. Elevation: **744'**  
Topography:  Hill  Slope  Upland  Valley

19. Remarks: **We do not install pumps.**

20. Water well contractor's certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
**Hoobler Drilling Co.** **323**  
Business name License No.  
Address **St. Marys, Ks. 66536**  
Signed **Don Hoobler** Date **4-5-77**  
Authorized representative

(Use a second sheet if needed)

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

M1-1023

T 10 S 12 E 16 Sec 1/4 1/4 1/4