


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

ACC

1 Location of well:	County Shawnee	Township name	Fraction SWSWNE	Section number 15	Town number T10S	Range number R13E
Distance and direction from nearest town or city: Street address of well location if in city:			3 Owner of well: Wilt, Robert Address: Box 66 Rossville, Kansas			
Locate with "X" in section below: N  W X E S 1 Mile			Sketch map:			4 Well depth: 46 ft. Date of completion 11/11/75 Well diameter 10 in.
2 Type and color of material			From		To	
			Top Soil		0 6	
			Brown Clay with Fine Sand		6 18	
			Yellow Lime		18 27	
			Gray Shale with Sand		27 38	
			Blue Shale		38 46	
			5 <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>			
			7 Casing: Material PVC Height: above /below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 72 in. Diam. 5 " Weight 300 lbs./ft. ___ in. to ___ ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No ___ in. to ___ ft. depth			
			8 Screen: Manufacturer Modern pipe Type PVC Dia. 5 inch Slot/gauze ___ Length 20 Set between 26 ft. and 46 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material ___			
			9 Static water level: 18 ft. below land surface Date 11/11/75			
			10 Pumping level below land surfaces: ___ ft. after ___ hrs. pumping ___ g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield 15 g.p.m.			
			11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ___			
			12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade			
			13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> ___ Depth: From 3 ft. to 13 ft.			
			14 Nearest source of possible contamination: ft. 20 Direction West Type Ditch Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
			15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Pumpco Model number 102S711 Volts 230 Length of drop pipe 47 ft. capacity 10 g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
16 Remarks: elevation 950' Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <i>James Dullery</i> License No. 418 Business name Route 10 Topeka Address Janette Cummings Signed 11/25/75 Authorized representative			

10S 13E 15 SW SW NE

BR=932

▽ = 932