WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)
Topeka, Kansas 66620

			A C	A			opeka, Kansas 66620	
• .	County	Fraction F S W		Section number		Township number	Range number	
1. Location of well:	Shawnee		NE 1/4		19	⊤ 10S	s R 13E	(19 /w
Possville Ks. & 12 mi. North. R.R. or street:						rold Reser	66533	
4. Locate with "X" i		Sketch map:				6. Bore hole dia. 30 Well depth 80 ft.	in. Completion date 3	-2-77
NW NEX-						7 Cable tool Rotary Driven Dug Hollow rod Jetted Bored X_ Reverse rotary 8. Use: Domestic Public supply Industry X_ Irrigation Air conditioning Stock Lawn Oil field water Other		
SW SE						9. Casing: Materia Trans Height Above to below Threaded Welded Surface in. RMP PVC Weight lbs./ft.		
1				Т_ 1		Dia.16_ in. to 41_ ft. d Dia in. to ft. d	epth Wall Thickness: ir	iches or
5. Type and color of material				From	То	10. Screen: Manufacturer		
Black gumbo				0	5	Type Transite	Dia. 16"	
Hard brown silt				5	26		1_ft. and54	6 ·
Fine brown sand & med. brown sand				26	32	Gravel pack? Y.E.S. Size	and 80 range of material 5/8	
Med. brown gravel				32	38	11. Static water level: 24 ft. below land:	mo surface Date <u>12–20</u>	./day/yr. -7 6
Med. to large brown gravel				38	48	12. Pumping level below to	and surfaces: hrs. pumping 1000	_ g.p.m.
Med. to large gray gravel				48	55	33 ft. after 3 Estimated maximum yield =	_ hrs. pumping 1250	_ g.p.m. g.p.m.
Med. to large gray gravel & green clay				55	56	13. Water sample submitted		./day/yr.
Med. to large grown gravel				56	57	14. Well head completion:		
Small brown gravel & fine sand				57	71	Pitless adapter	Inches above	grade
Med. to large brown gravel				71	80	With: Neat cement _ Depth: From 0 ft. 1	Bentonite	Concrete
Gray shale-stopped.				80		16. Negrest source of possi	ble contamination: dr	ainage tch
						Well disinfected upon com	pletion?Yes	
						17. Pump: Manufacturer's name	X. Not installed	
	* *					Model number	— HP — Vo — ft. capacity —	1
						Type: Submersible	Turbir	
(Use a second sheet if needed)						Jet Centrifugal	Recipr	ocating
18. Elevation: 19. Remarks: AUL We do not install pumps.						20. Water well contractor' This well was drilled under		s report
						is true to the best of my knowledge and belief. Hoobler Drilling Co. 323		
Topography:Hill						Business name		
Slope						Signed New Hor	1/1	3-3-7
Valley	ue and nink conies to the Departmen	t of Health and Environment				AUTHORIZEG	Form W	I VC-5

Forward the white, blue and pink copies to the Department of Health and Environment

BR = 860

= 916