

217

St Marys

OK

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

LS 8/19/81
FCOK

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Shawnee		Fraction NE NW SW 1/4 NE 1/4 NW 1/4 SW 1/4		Section number 31	Township number T 10S	Range number S R 13E	E/W
2. Distance and direction from nearest town or city: 4 mi. west of Rossville, Ks. on County Rd., & 3/4 mi. south.				8. Owner of well: Scott Kelsey			
Street address of well location if in city:				R.R. or street: City, state, zip code Rossville, Kansas 66533			
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: <i>County Rd. or Maple Hill Rd</i> <input checked="" type="checkbox"/> Northwood Farm		6. Bore hole dia. 30 in. Completion date 11-7-77 Well depth 46 ft.		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
Light brown sandy soil		0	1	9. Casing: Material Trans Height (Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 20 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 75			
Fine brown sand		1	14	10. Screen: Manufacturer's name Johnson Well Casing Co. Type Transite Dia. 16" Slot/gauze 1/8 x 8 Length 26 Set between 20 ft. and 46 ft. ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 1/8-1/4"			
Small brown gravel		14	17	11. Static water level: <input type="checkbox"/> mo./day/yr. 14 ft. below land surface Date 11-7-77			
Med. to large brown gravel		17	22	12. Pumping level below land surfaces: 26 ft. after 1 hrs. pumping 800 g.p.m. 36 ft. after 3 hrs. pumping 1000 g.p.m. Estimated maximum yield 1200 g.p.m.			
Med. to large green gravel		22	26	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date			
Med. to large green gravel & gray clay		26	35	14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade			
Med. gray gravel		35	41	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
Med. to large gray gravel		41	46	16. Nearest source of possible contamination: ft. 700 Direction north Type swale Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
Green shale-stopped.		46		17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(Use a second sheet if needed)				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hoobler Drilling Co. 323 Business name License No. Address Sh. Marys, Ks. 66536 Signed [Signature] Date 11-30 Authorized representative			
18. Elevation: 931.6m Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	19. Remarks: This is a rebuild well. Replacement well: old well about 10' away. CASING in old well holes						

NO

T
R
Sec
10 130 31
SWMSW