

99

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

ABA

1. Location of well:		County Shawnee	Fraction NE 1/4 NW 1/4 NE 1/4	Section number 9	Township number T 10 S	Range number R 14 E	
2. Distance and direction from nearest town or city: 2 mi N.			3. Owner of well: DAVID Besomiers				
Street address of well location if in city: Grove			R.R. or street: RTI				
			City, state, zip code: Silver Lake, Kansas 66539				
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 5 in. Completion date 5-30-78		
					Well depth 100 ft.		
					7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
					8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
					9. Casing: Material PVC Height: Above or below		
					Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in.		
					RMP <input type="checkbox"/> PVC BLUE Weight 2.74 lbs./ft.		
					Dia. 5 in. to 100 ft. depth Wall Thickness: inches or		
					Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. .258		
5. Type and color of material		From	To		10. Screen: Manufacturer's name PUMPE		
Top Soil w/ Bolders		0	2		Type PVC Dia. 5"		
Brown Clay		2	21		<input checked="" type="checkbox"/> gauze 020 Length 10'		
Blue Shale		21	23		Set between 15 ft. and 25 ft.		
Gray limestone		23	24		Gravel pack? <input checked="" type="checkbox"/> Size range of material 030/060		
Brown limestone		24	25		11. Static water level: 15 ft. below land surface Date 5-30-78		
Gray Shale & limestone		25	100		12. Pumping level below land surfaces: Air Test		
					____ ft. after ____ hrs. pumping ____ g.p.m.		
					____ ft. after ____ hrs. pumping ____ g.p.m.		
					Estimated maximum yield 10 g.p.m.		
					13. Water sample submitted: ____ mo./day/yr.		
					Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date		
					14. Well head completion: Top Cap		
					____ Pitless adapter 24 inches above grade		
					15. Well grouted? YES		
					With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete		
					Depth: From 0 ft. to 10 ft.		
					16. Nearest source of possible contamination:		
					ft. 500' Direction N. Type Creek		
					Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
					17. Pump: <input checked="" type="checkbox"/> Not installed		
					Manufacturer's name		
					Model number ____ HP ____ Volts ____		
					Length of drop pipe ____ ft. capacity ____ g.p.m.		
					Type:		
					____ Submersible ____ Turbine		
					____ Jet ____ Reciprocating		
					____ Centrifugal ____ Other		
					(Use a second sheet if needed)		
18. Elevation: 1030		19. Remarks: For owner to install slabs				20. Water well contractor's certification:	
Topography:						This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
<input checked="" type="checkbox"/> Hill						STRADER Del q Co 1822	
____ Slope						Business name License No.	
____ Upland						Address RTI Holton, ks	
____ Valley						Signed Dale Parker Date 6-2-78	
						Authorized representative	

T
R
W
-
9
NE NW NE
1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5