

NE & NW

128

TYPEWRITER OR BALL
PEN-PRESS FIRMLY,
EVENLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County LEAVENWORTH	Fraction SW 1/4 NW 1/4 NE 1/4	Section number 8	Township number T 10 S	Range number R 21 E
2. Distance and direction from nearest town or city: Street address of well location if in city:	1 1/2 M. WEST OF JARDALO ON 8 Hwy.		3. Owner of well: HOMER WILLITS R.R. or street: R.R. #1 City, state, zip code: Leavenworth Ks. 66048		
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. 5 1/2 in. Completion date 9-21-77 Well depth 150 ft.		
5. Type and color of material	From	To	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Surface	0	3	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
drift	3	25	9. Casing: Material _____ Height: Above or below _____ Threaded _____ Welded _____ Surface _____ in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. 5 in. to 150 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. _____		
shale	25	121	10. Screen: Manufacturer's name NONE Type _____ Dia. _____ Slot/gauze _____ Length _____ Set between _____ ft. and _____ ft. Gravel pack? YES Size range of material 1/4/3/8		
shale	121	146	11. Static water level: 15 ft. below land surface Date 9-21-77 mo./day/yr		
sandstone	146	150	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 30 g.p.m.		
shale		150	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
total depth		150	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade		
			15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From 4 ft. to 15 ft.		
			16. Nearest source of possible contamination: ft. 150 Direction south Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation: Topography: Hill <input checked="" type="checkbox"/> Slope Upland Valley	19. Remarks: Customer is aware of State regulations and agrees to install a 4" square reinforced concrete platform around top of well. 975' Homer Willits		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. R.G. BLAZE Drilling Co 350 Business name License No. _____ Address 121 S. CHESTER-OLA Signed Alan Willet Date 10-21-77 Authorized representative		

BR elev = 950

7-760

1/4
66048
KS