

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.


WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

sent 3-22-76

UBRT
Vid
R

on border
or cap/c
well code

1. Location of well:		County Leavenworth	Fraction SW 1/4 SE 1/4 SW 1/4	Section number 9	Township number T 10 S R 22	Range number EW
2. Distance and direction from nearest town or city: Street address of well location if in city: 1 3/4 miles west Of Fairmount, Ks.			3. Owner of well: Mr. James Siegert R.R. or street: 1429 Kiowa City, state, zip code: Leavenworth, Kansas			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. <u>8</u> in. Completion date 2-27-76 Well depth 153 ft.	
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top Soil		0	3	9. Casing: Material <u>Plu</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>18</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. <u>5</u> in. to <u>41</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>250W</u>		
Clay		3	15	10. Screen: Manufacturer's name <u>Vinylplex, Inc.</u> Type <u>PVC</u> Dia. _____ Slot/gauze <u>06 1/16</u> Length _____ Set between <u>10</u> ft. and <u>55</u> ft. _____ ft. and _____ ft. Gravel pack? <u>Yes</u> Size range of material <u>1/8</u>		
Soft Sandy Clay		15	30	11. Static water level: _____ mo./day/yr. <u>50</u> ft. below land surface Date 2-27-76		
Gravel (Water)		30	55	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>over 10</u> g.p.m.		
Sandy Shale		55	153	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>18</u> inches above grade		
				15. Well grouted? <u>Yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>3</u> ft. to <u>23</u> ft.		
				16. Nearest source of possible contamination: ft. <u>300</u> Direction <u>north</u> Type <u>septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: _____ Not installed Manufacturer's name <u>Jacuzzi</u> Model number <u>5SUB</u> HP <u>1/2</u> Volts <u>220</u> Length of drop pipe <u>60</u> ft. capacity <u>10</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation: <u>940'</u>		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>BREUER, INC.</u> <u>174</u> Business name License No. Address <u>Box 147 Basehor, Ks. 66007</u> Signed <u>[Signature]</u> Date <u>3/17/76</u> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

BR elw = 885 3-890

10 220
- 9 SW SE SW
1/4 1/4 1/4 1/4