

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Leavenworth	Fraction NE 1/4 SW 1/4 SE 1/4 SW 1/4	Section number 18	Township number T 10 S R	Range number 22	
2. Distance and direction from nearest town or city: Street address of well location if in city: 2 miles north 3 1/2 miles west of Bashor, Ks.			3. Owner of well: Robert E. Davoren R.R. or street: 630 E. 7th City, state, zip code: Tonganoxie, Kansas 66086				
4. Locate with "X" in section below: Sketch map: N W E S			6. Bore hole dia. <u> </u> in. Completion date 7-3-79 Well depth 100 ft.				
5. Type and color of material			From		To		
			Top Soil		0	3	
Clay		3	18			7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Clay with sand & gravel		18	25			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Shale		25	55			9. Casing: Material <u>PL</u> Height: <u>Above or below</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>18</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u> </u> lbs./ft. Dia. <u>5</u> in. to <u>102</u> depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>265</u>	
Sandy Shale		55	91			10. Screen: Manufacturer's name (Slotted Pipe) Vinylplex, Inc. Type <u>PVC</u> Dia. <u>5"</u> Slot/gauze <u>.06 1/16</u> Length <u>15'</u> Set between <u>20</u> ft. and <u>25</u> ft. <u>80</u> ft. and <u>90</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4 - 1/8</u>	
Lime		91	100			11. Static water level: <u> </u> mo./day/yr. <u>10</u> ft. below land surface Date 7-3-79	
						12. Pumping level below land surfaces: <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>2</u> g.p.m.	
						13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>	
						14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>18</u> Inches above grade	
						15. Well grouted? <u>Yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>3</u> ft. to <u>15</u> ft.	
						16. Nearest source of possible contamination: ft. <u>400</u> Direction <u>east</u> Type <u>septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
						17. Pump: Not installed Manufacturer's name <u>Jacuzzi</u> Model number <u>5S4B</u> HP <u>1/2</u> Volts <u>220</u> Length of drop pipe <u>90</u> ft. capacity <u>10</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation: <u>902 ft</u> Topography: <u>Ru</u> <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: 130 gallon storage			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. BREUER, INC. <u>174</u> Business name License No. Address <u>Box 147, Bashor, Ks.</u> Signature <u>[Signature]</u> Date <u>7-11</u> Authorized Representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

T
10
R
22
W
18
Sec
1/4 SW
1/4 SE