

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Leavenworth	Fraction SW_{1/4} SE_{1/4} SE_{1/4}	Section number 21	Township number T 10 S R 22 21 (EW)	Range number	
2. Distance and direction from nearest town or city: 1 mile north &		3. Owner of well: Mr. Stanley Greer		Street address of well location if in city: 2 miles west of Basehor			R.R. or street: 2945 N. 156th St., Box 313
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>8</u> in. Completion date 6-11-79			
		Well depth: 138 ft.		7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		9. Casing: Material PL. Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP: <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 139 depth Wall thickness: inches or Dia. _____ in. to _____ ft. depth gage No. .265			
5. Type and color of material		From	To	10. Screens: Manufacturer's name (Slotted Pipe (Vinylplex, Inc.)) Type PVC Dia. 5" Slot/groze .06 1/16 Length 40' Set between 98 ft. and 138 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4-1/8			
Top Soil		0	3	11. Static water level: _____ mo./day/yr. 75 ft. below land surface Date 6-11-79			
Clay		3	30	12. Pumping level below land surface: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 20 g.p.m.			
Sand		30	45	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____			
Blue Mud		45	76	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 inches above grade			
Drift		76	97	15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 15 ft.			
Sandstone - Gray		97	136	16. Nearest source of possible contamination: ft. 100 Direction SW Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Lime		136	138	17. Pump: _____ Not installed Manufacturer's name Jacuzzi Model number 7S4B HP 3/4 Volts 220 Length of drop pipe 128 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(Use a second sheet if needed)				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. BREUER, INC. 174 Business name _____ License No. _____ Address Box 147, Basehor, Ks. Signed <i>[Signature]</i> Date 6-15-79			
18. Elevation:	19. Remarks:		20. Water well contractor's certification:				
Topography: ____ Hill ____ Slope ____ Upland ____ Valley							