

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 57a-1201-1215

Bureau of Department of Health and Environment-Division of Environment
Water well Contractors,
Topeka, Kansas 66620

1. Location of well: County **Leavenworth** Section **SW 1/4 SE 1/4 SW 1/4** Section number **26** Township number **T 10 S R 22** Range number **(EAW)**

2. Distance and direction from nearest town or city: **In the City of Basehor 600 ft. North of #1 Basehor Water** 3. Owner of well: **Rural Water District No. 4 Basehor, Kansas 66007**

Locate with "X" in section below. Sketch map: **Tower**

THIS IS A TEST HOLE FOR RURAL WATER DISTRICT NO. 4, BASEHOR, KANSAS, LEAVENWORTH COUNTY

4. Bore hole dia. **8** in. Completion date **5-16-79**
 5. Well depth **130** ft.
 6. Cable tool: Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary
 7. Use: Domestic Public supply Industry
 Irrigation Air conditioning Stock
 Lawn Oil field water Other
 8. Casings: Material _____ Height: Above or below
 Threaded _____ Welded _____ Surface _____ in.
 RMP _____ PVC _____ Weight _____ lbs./ft.
 Dia. _____ in. to _____ ft. depth Wall thickness: inches or
 Dia. _____ in. to _____ ft. depth gage No. _____

9. Type and color of material	From	To
Top Soil	0	3
Clay	3	22
Sandy Clay	22	38
Sandy Clay & Show of Gravel	38	40
Sandy Clay	40	52
Blue Mud	52	98
Sandstone - Gray	98	102
Shale - Sandy	102	109
Sandstone - Gray (Sandy)	109	115
Shale - (Sandy)	115	130

10. Screens: Manufacturer's name _____
 Type _____ Dia. _____
 Slot/gauze _____ length _____
 Sp. between _____ ft. and _____ ft.
 _____ ft. and _____ ft.
 Gravel pack? _____ Size range of material _____
 11. Static water level: _____ mo./day/yr.
 _____ ft. below land surface Date _____
 12. Pumping level below land surfaces:
 _____ ft. after _____ hrs. pumping _____ g.p.m.
 _____ ft. after _____ hrs. pumping _____ g.p.m.
 Estimated maximum yield _____ g.p.m.
 13. Water sample submitted: _____ mo./day/yr.
 Yes _____ No _____ Date _____
 14. Well head completion:
 _____ Pitless adapter _____ inches above grade
 15. Well grouted? _____
 With: _____ Neat cement _____ Bentonite _____ Concrete
 Depth: From _____ ft. to _____ ft.
 16. Nearest source of possible contamination:
 ft. _____ Direction _____ Type _____
 Well disinfected upon completion? Yes _____ No _____
 17. Pump: _____ Not installed
 Manufacturer's name _____
 Model number _____ HP _____ Volts _____
 Length of drop pipe _____ ft. capacity _____ g.p.m.
 Type:
 _____ Submersible _____ Turbine
 _____ Jet _____ Reciprocating
 _____ Centrifugal _____ Other _____

18. Elevation: **1107**
 Topography: _____ Hill _____ Slope _____ Upland _____ Valley _____
 19. Remarks: **APPROXIMATELY 2 GPM IN SAND & CLAY TEST NOT USED. FILLED TOP TO BOTTOM WITH NEAT CEMENT AND CLAY.**

20. Water well contractor's certification:
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
BREUER, INC. **174**
 Business name License No.
 Address **Box 1416 Basehor, Ks.**
 Signed *[Signature]* Date **5-16-79**