

251

R

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Leavenworth	Fraction SE SE NE NE 1/4 NE 1/4 SE 1/4	Section number 26	Township number T 10 S R	Range number 22 (E/W)
2. Distance and direction from nearest town or city: 1 mile north of Basehor, Kansas			3. Owner of well: Mr. Curtis Freeman R.R. or street: 7542 Lyon City, state, zip code: Kansas City, Kansas 66111		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. 8 in. Completion date 10-25-77 Well depth 103 ft.
Top Soil			0	3	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Clay			3	15	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Sandy Clay - Light Gravel			15	47	9. Casing: Material PL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 10 1/2 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. .265
Blue Mud			47	52	10. Screen: Manufacturer's name (Slotted Pipe) Type PVC Dia. 5" Slot/gauze .06 1/16 Length 26" Set between 52 ft. and 78 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 - 1/8"
Sandstone			52	78	11. Static water level: _____ mo./day/yr. 30 ft. below land surface Date 10-25-77
Lime			78	99	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 3 g.p.m.
Shale			99	100	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
T. D.			103		14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 Inches above grade
					15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 15 ft.
					16. Nearest source of possible contamination: ft. 150 Direction east Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: _____ Not installed Manufacturer's name Jacuzzi Model number 554B HP 1/2 Volts 220 Length of drop pipe 93 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation: 979			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. BREUER, INC. Box 147 Business name _____ Kansas No. _____ Address 174 Basehor, Ks. 66007 Signed David R. Breuer Date _____ Authorized representative		
19. Remarks: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

10 220 26 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

BR = 927 2 949