

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: Levenworth County Levenworth Fraction NW 1/4 NW 1/4 SW 1/4 Section number 108 27 Township number T 10S S R 22E E/W Range number

2. Distance and direction from nearest town or city: 1 mi NW Baserhor, Ks. 3. Owner of well: Raymond E. Dramann
R.R. or street: RR1
City, state, zip code: Baserhor, Ks.

4. Locate with "X" in section below: Sketch map:

6. Bore hole dia. 6 3/4 in. Completion date 9-20-76
Well depth 121 ft.

7. Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary

8. Use: Domestic Public supply Industry
 Irrigation Air conditioning Stock
 Lawn Oil field water Other

9. Casing: Material steel Height: Above or below
Threaded Welded Surface 12 in.
RMP PVC Weight * lbs./ft.
Dia. 6 3/4 in. to 4 1/2 ft. depth Wall Thickness: inches or
Dia. 2 in. to 121 ft. depth Gauge No. _____

5. Type and color of material	From	To
clay (sandy)	0	28
gravel	28	40
sand (brown)	40	48
shale (grey)	48	62
sand (grey) sandstone	62	92
lime (dark)	92	102
shale (dark)	102	106
lime	106	109
shale (grey)	109	121

10. Screen: Manufacturer's name Robin Tech.
Type PVC Dia. _____
Slot/gauge drill/slot length 85
Set between 36 ft. and 121 ft.
Gravel pack? yes no Size range of material _____

11. Static water level: _____ mo./day/yr.
30' ft. below land surface Date 9-20-76

12. Pumping level below land surfaces:
_____ ft. after _____ hrs. pumping _____ g.p.m.
_____ ft. after _____ hrs. pumping _____ g.p.m.
Estimated maximum yield 20GPM g.p.m.

13. Water sample submitted: _____ mo./day/yr.
 Yes No Date _____

14. Well head completion:
 Pitless adapter _____ Inches above grade

15. Well grouted? yes
With: Neat cement Bentonite Concrete
Depth: From 5 ft. to 30 ft.

16. Nearest source of possible contamination:
ft. 100' Direction SE Type septic
Well disinfected upon completion? Yes No

17. Pump: _____ Not installed
Manufacturer's name Gould's
Model number 7EH HP 2 Volts 230
Length of drop pipe 110 ft. capacity 8 g.p.m.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

18. Elevation: 925'
Topography:
 Hill
 Slope
 Upland
 Valley

19. Remarks: Customer is aware of State regulation and agrees to install a 4' square re-enforced concrete platform around top of well.
Raymond E. Dramann

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
F. E. Young Drilling Co. 240
Business name _____ License No. _____
Address 6835 Robinhood Ln.
Signed F.E. Young Date 9-24-76
Authorized representative

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5