


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Leavenworth	Fraction SW 1/4 SW 1/4 SE 1/4	Section number 27	Township number T 10 S R 22	Range number 22
2. Distance and direction from nearest town or city: m LOT 5, RANKIN Street address of well location: if in city: ADDITION, BASEHOR, KS.			3. Owner of well: Frank Thorne (Realtor) R.R. or street: 100 Highland City, state, zip code: Lansing, Kansas			
4. Locate with "X" in section below: N.  W E S 1 Mile			Sketch map:			6. Bore hole dia. 8 in. Completion date 8-30-78 Well depth 90 ft.
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Top Soil			0	8	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Drift			8	18	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 6 in. to 63 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. 188	
Blue Mud			18	32	10. Screen: Manufacturer's name (Slotted Pipe) Type Steel Dia. 6 1/4" Slot/gauze 1/4" Length 5' Set between 55 ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 - 1/8	
Shale			32	50	11. Static water level: 23 ft. below land surface Date 8-30-78 mo./day/yr.	
Coarse Sand			50	55	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
Gravel			55	60	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
Lime			60	79	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 Inches above grade	
Shale			79	84	15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 15 ft.	
Lime			84	90	16. Nearest source of possible contamination: neighborhood ft. 300' Direction south Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
(Use a second sheet if needed)			17. Pump: _____ Not installed Manufacturer's name BREUER, INC. Model number 534B HP 1 1/2 Visits Length of drop pipe 80 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
			18. Elevation: _____ Topography: _____ <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks:	