

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

AAA

1. Location of well: County **Leavenworth** Fraction **NE 1/4 NE 1/4 NE 1/4** Section number **31** Township number **T 10 S R 22** Range number **EW**

2. Distance and direction from nearest town or city: **2 miles west east of** Street address of well location if in city: **Basehor, Kansas**  
3. Owner of well: **Sid & Barbara Kelley** R.R. or street: **7930 Sandusky** City, state, zip code: **Kansas City, Kansas**

4. Locate with "X" in section below: Sketch map:  
N  
W E  
S  
1 Mile

6. Bore hole dia. **8** in. Completion date **5-19-77**  
Well depth **90** ft.

7.  Cable tool  Rotary  Driven  Dug  
 Hollow rod  Jetted  Bored  Reverse rotary

8. Use:  Domestic  Public supply  Industry  
 Irrigation  Air conditioning  Stock  
 Lawn  Oil field water  Other

9. Casing: Material **PL** Height: Above or below  
Threaded  Welded  Surface **18** in.  
RMP  PVC  Weight  lbs./ft.  
Dia. **6** in. to **47** ft. depth Wall Thickness: inches or  
Dia.  in. to  ft. depth Gauge No. **280**

5. Type and color of material	From	To
Top Soil	0	1
Clay	1	12
Sandstone - Yellow	12	20
Sandy Shale - Gray	20	40
Sandstone - Gray	40	62
Sandy Lime	62	72
<del>Shale</del> Shale & Slate	72	78
Lime	78	82
Shale	82	90
(Use a second sheet if needed)		

10. Screen: Manufacturer's name **NONE**

Type  Dia.   
Slot/gauze  Length   
Set between  ft. and  ft.  
 ft. and  ft.  
Gravel pack?  Size range of material

11. Static water level:  mo./day/yr.  
**40** ft. below land surface Date **5-19-77**

12. Pumping level below land surfaces:  
 ft. after  hrs. pumping  g.p.m.  
 ft. after  hrs. pumping  g.p.m.  
Estimated maximum yield **1 before shot** g.p.m.

13. Water sample submitted:  mo./day/yr.  
Yes  No  Date

14. Well head completion:  Pitless adapter **18** Inches above grade

15. Well grouted? **Yes**  
With:  Neat cement  Bentonite  Concrete  
Depth: From **3** ft. to **47** ft.

16. Nearest source of possible contamination:  
ft. **125'** Direction **east** Type **septic**  
Well disinfected upon completion?  Yes  No

17. Pump:  Not installed  
Manufacturer's name **Jacuzzi**  
Model number **5SUB** HP **1/2** Volt **220**  
Length of drop pipe  ft. capacity **10** g.p.m.  
Type:  
 Submersible  Turbine  
 Jet  Reciprocating  
 Centrifugal  Other

18. Elevation: **8886**  
Topography:  
 Hill  
 Slope  
 Upland  
 Valley

19. Remarks:  
**2 1/4 gpm after shot. 500 Gallon Storage**

20. Water well contractor's certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
**BREUER, INC.** License No. **174**  
Business name **Box 147, Basehor, Ks. 66007**  
Address **Box 147, Basehor, Ks. 66007**  
Signed **[Signature]** Date **5/24/77**

T 10 S R 22 EW  
31  
NE 1/4 NE 1/4 NE 1/4