

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

CDC

12 BRT

1. Location of well:		County Leavenworth	Fraction SW 1/4 SE 1/4 SW 1/4	Section number 6	Township number T 10 S R 22	Range number 22
2. Distance and direction from nearest town or city: 4 miles west of				3. Owner of well: Mr. R. Ruttan		
Street address of well location if in city: Fairmount, Kansas				R.R. or street:		
				City, state, zip code:		
4. Locate with "X" in section below:				Sketch map:		
				6. Bore hole dia. 8 in. Completion date 7-12-78 Well depth 100 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 102 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 265		
5. Type and color of material				From	To	
Top Soil				0	2	
Clay				2	3	
Sandy Clay with gravel				3	15	
Sand and Gravel				15	43	
Blue Mud				43	55	
Sand and Gravel				55	70	
Lime				70	72	
Shale				72	100	
						10. Screens: Manufacturer's name (Slotted Pipe) Vinylplex, Inc. Type PVC Dia. 5" Slot/gauze 06 1/16 Length 40' Set between 20 ft. and 60 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 - 1/8
						11. Static water level: 23 ft. below land surface Date 7-12-78 mo./day/yr.
						12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 3 g.p.m.
						13. Water sample submitted: ____ Yes <input checked="" type="checkbox"/> No Date ____ mo./day/yr.
						14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 Inches above grade
						15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 115 ft.
						16. Nearest source of possible contamination: ft. 700' Direction south Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name XXXXXX Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation: 960		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. BREUER, INC. 174 Business name License No. Address Box 147, Basehor, Ks. Signed [Signature] Date 7/13/78		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

BR elev = 890

▽ = 937

✓