

221

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

DAD

why changed? must be!!
Kansas Department of Health and Environment
Division of Environment
Water Well Contractors
Topeka, Kansas 66620

1. Location of well:		County Leavenworth	Fraction SE 1/4 NE 1/4 SE 1/4	Section number 21	Township number T 10 S R 22 E	Range number 22
2. Distance and direction from nearest town or city: Street address of well location if in city:				3. Owner of well: R.R. or street: City, state, zip code:		
2 miles SW of Fairmount, Kansas				Mr. Bill Rains 6308 Georgia Kansas City, Kansas		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 10-2-78 Well depth 114 ft.		
				7. Cable to <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia 5 in. to 115 ft. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; Gage No. 265		
				10. Screen: Manufacturer's name (Slotted Pipe) Inyplex, Inc Type 1/8 Dia. 5 Slot/gauze 06 1/16 Length 22' Set between 90 ft. and 112 ft. ft. and <input type="checkbox"/> ft.		
				Gravel pack <input checked="" type="checkbox"/> Size range of material 1/4 - 1/8		
				11. Static water level: <input type="checkbox"/> mo./day/yr. 40 ft. below land surface Date 10-2-78		
				12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield over 30 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>		
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 inches above grade		
				15. Well grouted Yes With <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 15 ft.		
				16. Nearest source of possible contamination: ft. 50 Direction west Type laterals Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Jacuzzi Model number 5843 HP 1/2 Volt 220 Length of drop pipe 104 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)						
18. Elevation: 940		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. BREUER, INC. License No. 174 Business name Address Box 147, Bascher, Ka. Signed [Signature] Date 10-2-78 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

BR elev = 855

▽ = 900