


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

| | | | | | |
|---|-------------------------|--|--|---|------------------------|
| 1. Location of well: | County Wyandotte | Fraction SW 1/4 NE 1/4 SE 1/4 | Section number 34 | Township number T 10 S R 23 | Range number EW |
| 2. Distance and direction from nearest town or city: Street address of well location if in city: 1 mile south & 1 mile east of Piper, Ks. | | | 3. Owner of well: Mr. Jack Ulrich R.R. or street: 2741 Hutton Road City, state, zip code: Kansas City, Kansas 66109 | | |
| 4. Locate with "X" in section below: N W E S 1 Mile 1 Mile | | | Sketch map:  | | |
| 5. Type and color of material | | | From | To | |
| Top Soil | | | 0 | 2 | |
| Clay | | | 2 | 5 | |
| Sandy Clay | | | 5 | 19 | |
| Sandstone | | | 19 | 51 | |
| Sandstone - Gray | | | 51 | 54 | |
| Sandy Shale | | | 54 | 56 | |
| Sandstone - Gray | | | 56 | 65 | |
| Shale | | | 65 | 70 | |
| Lime | | | 70 | 81 | |
| Shale | | | 81 | 86 | |
| Lime | | | 86 | 90 | |
| (Use a second sheet if needed) | | | | | |
| 18. Elevation: 1100 | | 19. Remarks: 600 gallon storage | | 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. BREUER, INC. 174 Business name: Box 147, Basehor, Ks. License 86007 Address: Box 147, Basehor, Ks. Signed: Ronald A. Breuer Date 12/17/77 Authorized representative | |

| |
|---|
| 6. Bore hole dia. 8 in. Completion date 12-9-77 Well depth 90 ft. |
| 7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary |
| 8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other |
| 9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP 8 PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 8 in. to 24 ft. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. 10 gage |
| 10. Screen: Manufacturer's name NONE Type <input type="checkbox"/> Dia. <input type="checkbox"/> Slot/gauze <input type="checkbox"/> Length <input type="checkbox"/> Set between <input type="checkbox"/> ft. and <input type="checkbox"/> ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? NONE Size range of material <input type="checkbox"/> |
| 11. Static water level: <input type="checkbox"/> mo./day/yr. 30 ft. below land surface Date 12-9-77 |
| 12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 3 g.p.m. |
| 13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> |
| 14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 inches above grade |
| 15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 10 ft. |
| 16. Nearest source of possible contamination: ft. 100 Direction east Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |
| 17. Pump: Manufacturer's name Jacuzzi <input type="checkbox"/> Not installed Model number 5SLB HP 1/2 Volts 220 Length of drop pipe 80 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other |

10 230 34 SW NE 1/4