

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County WYANDOTTE	Fraction NW 1/4 NE 1/4 NE 1/4	Section number 23	Township number T 10 SOUTH S	Range number R 24 EAST E/W
2. Distance and direction from nearest town or city: 2 MILES NORTH OF KANSAS CITY, KANSAS Street address of well location if in city: NEARMAN POWER PLANT			3. Owner of well: SHARP BROS INC R.R. or street: 1014 E 19th ST City, state, zip code: KANSAS CITY, MO 64108		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 30 in. Completion date 9-29-78 Well depth 70 ft.	
		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other	
				9. Casing: Material STEEL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 12 in. to 30 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. .188	
5. Type and color of material			From	To	10. Screen: Manufacturer's name _____ JOHNSON Type IRRIGATOR Dia. 12" Slot/gauze 1025 Length 40' Set between 30 ft. and 70 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/8 GR
					11. Static water level: _____ mo./day/yr. 15 ft. below land surface Date 9-30-78
					12. Pumping level below land surfaces: 35 ft. after 24 hrs. pumping 400 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 400 g.p.m.
					13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
					14. Well head completion: <input type="checkbox"/> Pitless adapter 24 Inches above grade
					<input checked="" type="checkbox"/> 15. Well grouted? NO With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From _____ ft. to _____ ft.
					16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: _____ Not installed Manufacturer's name LAYNE BOWLER Model number _____ HP 25 Volts 480 Length of drop pipe 60 ft. capacity 400 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. MOORE TRENCH AMERICAN COOP Business name _____ License No. _____ Address DOWNERS GROVE, ILL Signed [Signature] Date 2-10-79 Authorized representative
18. Elevation:	19. Remarks: #8 - DEWATERIZING				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

T
R
S
E
C
1/4
1/4
1/4
1/4
NW
NE
NE
NE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5