


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County WYANDOTTE	Fraction SW 1/4 NE 1/4 NE 1/4	Section number 23	Township number T 10 South S	Range number R 24 EAST E/W
2. Distance and direction from nearest town or city: 2 MILES NORTH OF KANSAS CITY, KANSAS Street address of well location if in city: NEARMAN POWER PLANT			3. Owner of well: SLAMP BROS INC R.R. or street: 1014 EAST 17th ST City, state, zip code: KANSAS CITY, MO 64108		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. 30 in. Completion date 10-26-78 Well depth 70 ft.
0- CLAY			0	2'	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
SANDY CLAY			2	6	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other
STIFF CLAY			6	17	9. Casing: Material STEEL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 28 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 12 in. to 70 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gage No. 1219
FINE SAND - Silty			17	37	10. Screen: Manufacturer's name _____ JOHNSON Type PERMATOR Dia. 12 Slot/gauze .025 Length 40 Set between -30 ft. and 70 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/8 GR
MED-FINE SAND			37	60	11. Static water level: _____ mo./day/yr. 17 ft. below land surface Date 10-26-78
FINE SAND			60	70	12. Pumping level below land surfaces: 30 ft. after 12 hrs. pumping 400 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 400 g.p.m.
					13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
					14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 28 Inches above grade
					15. Well grouted? _____ With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 10 ft.
					16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: _____ Not installed Manufacturer's name LAUNE BOWLER Model number 20HP Volts 480 Length of drop pipe 60 ft. capacity 400 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation: 752 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	19. Remarks: #8-DEWATERING USE		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. MOREBENCH AMERICAN Business name _____ License No. _____ Address DANNERS GROVE, ILL Signed [Signature] Date 2-10-79 Authorized representative		

T
R
W
S
E
C
10 240 23 SW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5