


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County WYANDOTT	Fraction SW 1/4 NE 1/4 NE 1/4	Section number 23	Township number T 10 South S	Range number R 24 East E/W
2. Distance and direction from nearest town or city: 2 MILES NORTH OF KANSAS CITY, KANSAS Street address of well location if in city: NEARMAN POWER PLANT			3. Owner of well: SHARP BROS R.R. or street: 1014 E 19th ST City, state, zip code: KANSAS CITY, MO 64108		
4. Locate with "X" in section below: N  W E S 1 Mile			Sketch map:		
5. Type and color of material			From	To	6. Bore hole dia. 30 in. Completion date 9-18-78 Well depth 71 ft.
Top Soil			0	3	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Clay			3	6	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other
Five Sands w/ clay			6	15	9. Casing: Material STEEL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 12 in. to 71 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 188
Clay			15	21	10. Screen: Manufacturer's name _____ JOHNSON Type IRRIGATOR Dia. 12" Slot/gauze 1025 Length 40' Set between 31 ft. and 71 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/8 GR
Silty Five Sands			21	36	11. Static water level: _____ mo./day/yr. 15 ft. below land surface Date 9-19-78
MED SAND			36	62	12. Pumping level below land surfaces: 31 ft. after 48 hrs. pumping 400 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 400 g.p.m.
Silty Sands			62	71	13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____
					14. Well head completion: <input type="checkbox"/> Pitless adapter 18 inches above grade
					<input checked="" type="checkbox"/> 15. Well grouted? No With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From _____ ft. to _____ ft.
					16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: _____ Not installed Manufacturer's name LAYNE BOWLER Model number _____ HP 20 Volts 480 Length of drop pipe 60 ft. capacity 400 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
			(Use a second sheet if needed)		
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	19. Remarks: # 8 - DEWATERING		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. MOORETRENCH AMERICAN Corp Business name _____ License No. _____ Address DANWORTH GROVE, ILL Signed [Signature] Date 2-10-79 Authorized representative		

T 10
R 24
E/W
23
SW NE SE
1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment.

Form WWC-5