


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County WYANDOTT	Fraction NE 1/4 NW 1/4 NE 1/4	Section number 23	Township number T 10 SOUTH S	Range number R 24 EAST E/W
2. Distance and direction from nearest town or city: 2 MILES NORTH OF KANSAS CITY, KANSAS Street address of well location if in city: NEARIZMAN POWER PLANT			3. Owner of well: SHARP BROS, FWC R.R. or street: 1014 E 19th ST City, state, zip code: KANSAS CITY, MO 64108		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. 30 in. Completion date 10-16-78 Well depth 62 ft.
Clay			0	12	7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
FINE SAND			12	23	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other
FINE SILTY SAND			23	28	9. Casing: Material STEEL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 20 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 1 1/2 in. to 2 1/2 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 1250
FINE MEDIUM SAND			28	39	10. Screen: Manufacturer's name _____ DOVER Type GRAVEL GUARD Dia. 18 Slot/gauze .060 Length 40 Set between 28 ft. and 68 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 70-62
MEDIUM COARSE SAND (silty)			39	57	11. Static water level: _____ mo./day/yr. 19 ft. below land surface Date 10-17-78
FINE MEDIUM SAND			57	68	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.
					13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____
					14. Well head completion: <input type="checkbox"/> Pitless adapter 20 inches above grade
					<input checked="" type="checkbox"/> 15. Well grouted? NO With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From _____ ft. to _____ ft.
					16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
			(Use a second sheet if needed)		
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	19. Remarks: PIEZOMETER		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. MORETREWELL AMERICAN Business name _____ License No. _____ Address DOWNERS GROVE, ILL Signed J. A. [Signature] Date 2-79 Authorized representative		

T
R
E
W
E
L
L
N
O
2
4
0
2
3
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5