

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County WYANDOTTE	Fraction NE 1/4 NW 1/4 NE 1/4	Section number 23	Township number T 10 SOUTH S	Range number R 24 EAST E/W	
2. Distance and direction from nearest town or city: 2 MILES NORTH OF KANSAS CITY, KANSAS Street address of well location if in city: NEARMAN POWER PLANT				3. Owner of well: SHARP BROS INC R.R. or street: 1014 E 19th ST City, state, zip code: KANSAS CITY, MO 64108			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile				Sketch map: 			
5. Type and color of material				From	To		
Clay				0	13		
Silty Sand				13	26		
FINE med SAND				26	37		
MED COARSE SAND				37	56		
FINE Silty SAND w/GR				56	59		
med SAND				59	67		
FINE Silty SAND w/GR				67	73		
(Use a second sheet if needed)							
6. Bore hole dia. 30 in. Completion date 10-20-78 Well depth 73 ft.		7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary					
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other							
9. Casing: Material STEEL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 12 in. to 33 ft. depth; Wall Thickness: inches or Dia. _____ in. to _____ ft. depth; gage No. 138							
10. Screen: Manufacturer's name JOHNSON Type IRRIGATOR Dia. 13" Slot/gouze 1025 Length 40' Set between 33 ft. and 73 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/8 GR							
11. Static water level: _____ mo./day/yr. 17 ft. below land surface Date 10-21-78							
12. Pumping level below land surfaces: 37 ft. after 48 hrs. pumping 400 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 400 g.p.m.							
13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____							
14. Well head completion: <input type="checkbox"/> Pitless adapter 24 Inches above grade							
15. Well grouted? NO With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From _____ ft. to _____ ft.							
16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No							
17. Pump: _____ Not installed Manufacturer's name LAYNE BOWLER Model number _____ HP 20 Vol 480 Length of drop pipe 63 ft. capacity 400 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other							
18. Elevation:		19. Remarks: #8 - DEWATERING				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. MORETRENCH AMERICAN CORP Business name _____ License No. _____ Address DOWNERS GROVE, ILL Signed [Signature] Date 2-79 Authorized representative	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley							

T 10 SOUTH S
R 24 EAST E/W
Sec 23
NE 1/4 NW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5