

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

MOD in CP

1. Location of well:		County WYANDOTT	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 14	Township number T 10 SOUTH S	Range number R 24 EAST E/W
2. Distance and direction from nearest town or city: 2 MILES NORTH OF KANSAS CITY, KANSAS Street address of well location if in city: NEACMAN POWER HOUSE				3. Owner of well: SHARP BROS FWC R.R. or street: 1014 E. 19ST City, state, zip code: KANSAS CITY, MO 64108		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 30 in. Completion date 10-30-78 Well depth 68 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry DEWATERING <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other <input checked="" type="checkbox"/>		
Top Soil		0	4	9. Casing: Material STEEL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 22 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 13 in. to 20 ft. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. 219		
clay		4	11	10. Screen: Manufacturer's name JOHNSON Type IRRIGATOR Dia. 12" Slot/gauze 025 Length 40' <input checked="" type="checkbox"/> Set between 28 ft. and 68 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/8 6/8		
FINE SAND		11	13	11. Static water level: <input type="checkbox"/> mo./day/yr. 17 ft. below land surface Date 11-1-78		
clay		13	15	12. Pumping level below land surfaces: 42 ft. after 72 hrs. pumping 400 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 400 g.p.m.		
FINE MED SAND		15	37	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
FINE SILTY SAND		37	43	14. Well head completion: <input type="checkbox"/> Pitless adapter 22 inches above grade		
MED to COARSE SAND		43	59	15. Well grouted? NO With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete <input checked="" type="checkbox"/> Depth: From 0 ft. to 10 ft.		
COARSE SAND		59	63	16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
MED to FINE SAND		63	68	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name LEO JACKET Model number <input type="checkbox"/> HP 25 Volts 480 Length of drop pipe 56 ft. capacity 400 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)						
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. MOETRENT AMERICAN 384 Business name DOWNERS LEAD WELL License No. <input type="checkbox"/> Address 1014 E. 19ST Signed A. O. S. Date 2-79 Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	DEWATERING 28-68'					

T 10 SOUTH S
R 24 EAST E/W
Sec 14