

24

where marked?

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County WYANDOTTE	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 14	Township number T10 SOUTH S	Range number R 24 EAST E/W
2. Distance and direction from nearest town or city: 2 MILES NORTH OF KANSAS CITY, KANSAS			3. Owner of well: SHARP BROSTWIC		
Street address of well location if in city: NEARMAN POWER HOUSE			R.R. or street: 104 E 19th ST		
4. Locate with "X" in section below:			City, state, zip code: KANSAS CITY MO 64108		
<p style="text-align: center;">Sketch map:</p> <div style="display: flex; align-items: center;"> <div style="writing-mode: vertical-rl; transform: rotate(180deg); margin-right: 5px;">1 Mile</div> </div>			6. Bore hole dia. 30 in. Completion date _____ Well depth 71 ft. 11-2-78		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other		
			9. Casing: Material STEEL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. 12 in. to 31 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 219		
5. Type and color of material			10. Screen: Manufacturer's name _____ JOHNSON Type IRRIGATOR Dia. 12" Slot/gauze .025 Length 40' Set between 30 ft. and 70 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/8 GR		
			11. Static water level: _____ mo./day/yr. 17 ft. below land surface Date 11-3-78		
			12. Pumping level below land surfaces: 39 ft. after 72 hrs. pumping 400 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 400 g.p.m.		
			13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
			14. Well head completion: _____ Pitless adapter 18 Inches above grade		
			15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 6 ft. to 12 ft.		
			16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: _____ Not installed Manufacturer's name LAYNE BOWLER Model number _____ HP 20 Volts 480 Length of drop pipe 60 ft. capacity 400 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. MOSEFENGT AMERICAN 389 Business name _____ License No. _____ Address DOWNERS GROVE, ILL Signed _____ Date 1-10-79 Authorized representative		
18. Elevation: 750 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		19. Remarks: #8 - DEWATERING 30-70			

T 10 R 24 E W 14 SE SE SE SE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

BR = 679

▽ = 723