

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>Wyandotte</b>	Fraction <b>NW 1/4 SE 1/4 NE 1/4</b>	Section number <b>13</b>	Township number T <b>10-S</b> S R <b>24</b>	Range number <b>EXX</b>
2. Distance and direction from nearest town or city: <b>5 mi ±</b>			3. Owner of well: <b>Shawnee Const. Co.</b>		
Street address of well location if in city:			R.R. or street: <b>6319 Kansas Avenue</b>		
			City, state, zip code: <b>Kansas City, KS 66111</b>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>30</b> in. Completion date <b>5-10-77</b>	
				Well depth <b>100</b> ft.	
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
5. Type and color of material		From To		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry	
				<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other	
Topsoil		0 2		9. Casing: Material <b>Steel</b> Height: Above or below	
Brown Silty clay - moist - stratified		2 10		Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>2'</b> above in.	
Silt - fine silty sand - wet		10 30		RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>33</b> lbs./ft.	
Brown gray medium sand - wet		30 50		Dia. <b>16</b> in. to <b>70</b> ft. depth Wall Thickness: inches or	
Gray medium coarse sand - wet		50 80		Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>1/4"</b>	
Gray medium coarse sand - trace of gravel		70 80		10. Screen: Manufacturer's name <b>Doerr</b>	
Medium sand-lignite - trace of - gravel		80 100		Type <b>Punched</b> Dia. <b>16"</b>	
Cobbles @ 95				Slot/gauze <b>1/16"</b> Length <b>30</b>	
				Set between <b>70</b> ft. and <b>100</b> ft.	
				Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>1/4"</b>	
				11. Static water level: <input type="checkbox"/> mo./day/yr.	
				<b>16</b> ft. below land surface Date <b>5-10-77</b>	
				12. Pumping level below land surfaces:	
				<b>50</b> ft. after <b>10</b> hrs. pumping <b>1500</b> g.p.m.	
				<input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m.	
				Estimated maximum yield <b>1500</b> g.p.m.	
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr.	
				Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>	
				14. Well head completion: <b>Temp. Dis. Head</b>	
				<input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
				15. Well grouted? <b>No</b>	
				With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete	
				Depth: From <input type="checkbox"/> ft. to <input type="checkbox"/> ft.	
				16. Nearest source of possible contamination:	
				ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/>	
				Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
				17. Pump: <input type="checkbox"/> Not installed	
				Manufacturer's name <b>Aurora</b>	
				Model number <input type="checkbox"/> HP <b>60</b> Volts <input type="checkbox"/>	
				Length of drop pipe <b>60</b> ft. capacity <b>7000</b> g.p.m.	
				Type:	
				<input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine	
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating	
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation: <b>743 KM</b>		19. Remarks: <b>This is a temporary well for dewatering purpose only. Upon completion of dewatering, casing and screen will be removed and remaining hole filled.</b>		20. Water well contractor's certification:	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley				This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
				Business name <b>Southern Wellpoint Co., Inc. #235</b> License No. <input type="checkbox"/>	
				Address <b>2935 N. Toledo, Tulsa, OK</b>	
				Signed <b>A.W. Macomber</b> Date <b>7-1-77</b>	
				Authorized representative	

T  
R  
W  
S  
E  
10 2 40 13 NW SE NE

Forward the white, blue and pink copies to the Department of Health and Environment

**A. W. Macomber, President**  
Form WWC-5