USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	WYANDOTTE	NW 1/4 NE 1/4 NE 1/4	13	T 10 S	R 24 E

2. Distance and direction from nearest town or city:

Street address of well location if in city:

3. Owner of well: Shawnee Const. Co.
R.R. or street: 6319 Kansas Ave
City, state, zip code: K.C., Ks.

4. Locate with "X" in section below: Sketch map:

N — NW — NE (X) — W — E — SW — SE — S — 1 Mile

6. Bore hole dia. 30 in. Completion date 7-14-77
Well depth 100 ft.

7. __ Cable tool __ Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored x Reverse rotary

8. Use: __ Domestic __ Public supply __ Industry
__ Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water x Other

9. Casing: Material steel Height: Above or below
Threaded ___ Welded x Surface 2' above in.
RMP ___ PVC ___ Weight 42 lbs./ft.
Dia. 16 in. to 60 ft. depth Wall Thickness: inches or
Dia. ___ in. to ___ ft. depth gage No. 1/4"

5. Type and color of material	From	To
Brown Silty Clay	0	10
Silty - For Sand	10	20
Coarse sand - to gravel	20	60
Fine Sand	60	70
Coarse sand gravel cobbles	70	100
@ 95		

(Use a second sheet if needed)

10. Screen: Manufacturer's name Johnson
Type irrigator Dia. 16"
Slot/gauze .010 Length 40'
Set between 60 ft. and 100 ft.
___ ft. and ___ ft.
Gravel pack? x Size range of material 1/4"

11. Static water level: mo./day/yr.
___ ft. below land surface Date ___

12. Pumping level below land surfaces:
45 ft. after 10 hrs. pumping 2000 g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield 2000 g.p.m.

13. Water sample submitted: mo./day/yr.
__ Yes x No Date ___

14. Well head completion: Temp. Dis. head
__ Pitless adapter ___ Inches above grade

15. Well grouted? no
With: ___ Neat cement ___ Bentonite ___ Concrete
Depth: From ___ ft. to ___ ft.

16. Nearest source of possible contamination:
ft. ___ Direction ___ Type ___
Well disinfected upon completion? ___ Yes x No

17. Pump: __ Not installed
Manufacturer's name F. Morse
Model number MC 14 HP 75 Volts ___
Length of drop pipe 60 ft. capacity 2500 g.p.m.
Type:
__ Submersible __ Turbine
__ Jet __ Reciprocating
__ Centrifugal __ Other

T — R — E W — Sec — 1/4 — 1/4 — 1/4

18. Elevation:

Topography:
__ Hill
__ Slope
__ Upland
x Valley

19. Remarks:

Our contract with Shawnee states "All holes shall be filled to the satisfaction of the owner and/or engineers at no cost to our firm.

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. #235
Southern Wellpoint Co., Inc.
Business name License No.
Address 2935 North Toledo Tulsa OK
Signed A. W. Macomber Date 5-23-78
Authorized representative

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

MI-1023