

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County <u>Wyandotte</u>		Fraction <u>NE 1/4 SE 1/4 SE 1/4</u>	Section number <u>14</u>	Township number <u>T 10 S R 24 E/W</u>	Range number
2. Distance and direction from nearest town or city: <u>in K.C. Ks.</u>		3. Owner of well: <u>Board of Public Utilities</u>			
Street address of well location if in city: <u>55th + Mo. River</u>		R.R. or street: <u>55th St. K.C. Ks.</u>			
City, state, zip code:					
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>22</u> in. Completion date <u>4-6-79</u>	
				Well depth <u>103</u> ft.	
5. Type and color of material		From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug	
<u>Sand fill</u>		<u>0</u>	<u>3'</u>	<input type="checkbox"/> Hollow rad <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
<u>Gray Sandy Silty Clay to Clayey Silt</u>		<u>3'</u>	<u>16'</u>	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry	
<u>Gray and Brown fine to coarse Sand w/tr of clay</u>		<u>16'</u>	<u>169'</u>	<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock	
				<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other	
				9. Casing: Material <u>Steel</u> Height: Above or below	
				Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12"</u> in.	
				RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.2</u> lbs./ft.	
				Dia. <u>16"</u> in. to <u>28</u> ft. depth Wall Thickness: inches or	
				Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>0.025</u>	
				10. Screen: Manufacturer's name <u>Dorr</u>	
				Type <u>Shutter</u> Dia. <u>16"</u>	
				Slot/gauze <u>0.050</u> Length <u>25'</u>	
				Set between <u>78</u> ft. and <u>103</u> ft.	
				<u> </u> ft. and <u> </u> ft.	
				Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material <u>1/8"</u>	
				11. Static water level: <u>17</u> ft. below land surface Date <u>4-6-79</u>	
				12. Pumping level below land surfaces:	
				<u>30</u> ft. after <u>4</u> hrs. pumping <u>1000</u> g.p.m.	
				Estimated maximum yield <u>1000</u> g.p.m.	
				13. Water sample submitted: <u> </u> mo./day/yr.	
				<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>	
				14. Well head completion: <u>12</u> inches above grade	
				<input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> <u>12</u> inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/> Yes	
				With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete	
				Depth: From <u>3</u> ft. to <u>20</u> ft.	
				16. Nearest source of possible contamination: <u>3000</u> ft. Direction <u>North</u> Type <u>Mo. River</u>	
				Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <u>Installed</u> Not installed	
				Manufacturer's name <u>and removed after</u>	
				Model number <u>Well #1 JP was completed</u>	
				Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m.	
				Type:	
				<input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine	
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating	
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation: <u>751</u>		19. Remarks:		20. Water well contractor's certification:	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		<u>Supply Well for Well #1 was plugged, please find plugging report. Note: Supply Well Pump was drilled 4-7-79 and plugged the same day.</u>		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
		<u>(1) Well was backfilled w/disinfected gravel</u>		<u>Layne-Western Co. Inc. 149</u>	
				Business name <u>1010 W St 39th K.C. Mo</u>	
				Address <u> </u> License No. <u> </u>	
				Signed <u>D.B. Rigg</u> Date <u>1/31/80</u>	
				Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Farm WWC-5

- (1) backfilled w/ gravel to within 20' of surface
- (2) backfilled w/ gravel to within 3' of surface
- (3) backfilled to surface w/natural soil

T 10 S R 24 E/W Sec 14 NE SE SE