

13

103 in 15

Also: Plugging Report

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County WYANDOTT	Fraction SW 1/4 NE 1/4 NE 1/4	Section number 23	Township number T10 SOUTH S	Range number R24 EAST E/W
2. Distance and direction from nearest town or city: 3 miles North of Kansas City, KA Street address of well location if in city: Near new power plant				3. Owner of well: SHAWB BROS INC R.R. or street: 1014 EAST 19th ST City, state, zip code: KANSAS CITY, MO 64108		
4. Locate with "X" in section below: N W E S 1 Mile				6. Bore hole dia. 30 in. Completion date _____ Well depth 72 ft. 9-4-78		
				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other		
5. Type and color of material				9. Casing: Material STEEL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 18 in. to 32 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 1250		
				10. Screen: Manufacturer's name _____ DAKOR Type GRAVEL GUARD Dia. 18" Slot/gauze .060 Length 40 Set between 32 ft. and 72 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/8 60		
Top Soil				11. Static water level: _____ mo./day/yr. 18 ft. below land surface Date 9-5-78		
clay				12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
Fine Sandy Silt				13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____		
clay				14. Well head completion: <input type="checkbox"/> Pitless adapter 18 Inches above grade		
FINE MED SAND				15. Well grouted? NO With: _____ Neat cement _____ Bentonite _____ Concrete Depth: From _____ ft. to _____ ft.		
Silty Fine SAND				16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? Yes _____ No _____		
MED SAND				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Fine SAND				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. MOOREHEAD AMERICAN CORP Business name _____ License No. _____ Address Downs Grove, Ill Signed [Signature] Date 2/21/79 Authorized representative		
<p>WELL CASING AND SCREEN REMOVED</p> <p>SAND BACK FILL PLACED FROM BOTTOM TO 15' BELOW EXISTING GRADE, CONCRETE plug placed FROM 15' TO 4' BELOW GRADE, SAND PLACED FROM 4' TO EXISTING GRADE</p> <p>(Use a second sheet if needed)</p>						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		COMPLETED 10-23-78				

T 10
 R 24
 W E
 S 23
 Sec
 1/4
 1/4
 1/4
 SW NE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5