


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County: CLAY		Fraction: SE 1/4 SE 1/4 SE 1/4		Section number: 19	Township number: T 10 S R 4	Range number: 4
2. Distance and direction from nearest town or city: 5-SOUTH Street address of well location if in city: WAKEFIELD				3. Owner of well: TOM ABBOTT R.R. or street: BOX 329 City, state, zip code: WAKEFIELD KANS 67487		
4. Locate with "X" in section below: Sketch map: 				6. Bore hole dia. 8 in. Completion date: 11/4/76 Well depth 120 ft.		
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3 lbs./ft. Dia. 5 in. to 120 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1214		
				10. Screen: Manufacturer's name PUMPCO Type PVC Dia. 5" Slot/gauge 1/16" Length 20' Set between 100 ft. and 120 ft. ft. and <input type="checkbox"/> ft. Gravel pack? YES Size range of material 4x24		
TOPSOIL				From	To	11. Static water level: 76 ft. below land surface Date 11/4/76 mo./day/yr.
BROWN CLAY				2	5	12. Pumping level below land surfaces: ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. ft. after N/A hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 20 g.p.m.
LIMESTONE				5	14	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____ mo./day/yr.
GRAY CLAY				14	24	14. Well head completion: <input type="checkbox"/> Pitless adapter 18 inches above grade
LIMESTONE				24	28	15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 83 ft. to 13 ft.
GRAY CLAY				28	47	16. Nearest source of possible contamination: SEPTIC ft. 100 Direction EAST Type TANK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
RED CLAY				47	57	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
LIMESTONE				57	87	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Geo Cox + Sons Inc 258 Business name License No. _____ Address CLIFTON KANS 67437 Signed George Cox Date 11/4/76 Authorized representative
BLUE SHALE				87	104	
LIMESTONE				104	116	
BLUE SHALE				116	120	
STOP				120		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 10 S R 4 W 4 E 19 SE SE SE 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5