

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County GEARY	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 32	Township number T 10 S R 5	Range number Q/W
2. Distance and direction from nearest town or city: 3 S			3. Owner of well: RICHARD ROTHFUS			
Street address of well location if in city: OF MILFORD			R.R. or street: City, state, zip code: JUNCTION CITY			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 4-12-77		
				Well depth 160 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PVC Height: above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC 94 Weight 2.58 lbs./ft. Dia. 5 in. to 160 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 2258		
5. Type and color of material		From	To	10. Screen: Manufacturer's name PUMPCO		
TOP SOIL		0	5	Type PVC Dia. 5		
SANDY CLAY		5	22	60 gauge 060 Length 40		
Limestone, grey, shale, grey		22	75	Set between 120 ft. and 160 ft.		
Shaley Limestone, grey		75	138	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 X 1/8		
Limestone, yellow		138	195	11. Static water level: _____ mo./day/yr. 120 ft. below land surface Date 4-12-77		
Shale, grey, black		195	160	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 40 g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				14. Well head completion: CAP <input type="checkbox"/> Pitless adapter 24 inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.		
				16. Nearest source of possible contamination: ft. 150 Direction W Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Strader Dalg Co Inc 182 Business name _____ License No. _____ Address RT 1 HOLTEN, KS Signed Dale Cushman Date 4-12-77 Authorized representative		
19. Remarks: OWNER WILL INSTALL SLAB						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5