

16

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

S E N I N E

1. Location of well: County Riley		Fraction NE 1/4 NE 1/4 NE 1/4 NE 1/4	Section number 6	Township number T 9 S	Range number R 6 E
2. Distance and direction from nearest town or city: 4 W OF K MANHATTAN		3. Owner of well: JACK NEEF		R.R. or street: RFD 2	
Street address of well location if in city:		City, state, zip code: MANHATTAN, KS			
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile		Sketch map: WATER WELL House 30' 200' SEPTIC TANK DRAINAGE		6. Bore hole dia. 10 in. Completion date _____ Well depth 120 ft. 11-5-75	
5. Type and color of material		From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Shale (Blue)		0	6	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Limestone (grey)		6	23	9. Casing: Material _____ Height: Above or below Threaded _____ Welded 9L Surface 24 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 2.33 lbs./ft. Dia. 5 in. to 120 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. _____	
Shale (grey)		23	69	10. Screen: Manufacturer's name PUMPCO Type PVC Dia. 5" <input checked="" type="checkbox"/> Slot gauge 80 Length 20 FT. Set between 100 ft. and 120 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 1/4 x 1/8	
Limestone (Brown)		69	81	11. Static water level: _____ mo./day/yr. 80 ft. below land surface Date 11-5-75	
Shale (Blue)		81	100	12. Pumping level below land surfaces: AIR TEST _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 30 g.p.m.	
Limestone (yellow-soft-broken)		100	105	13. Water sample submitted: _____ ma./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date _____	
Shale (Red)		105	110	14. Well head completion: NOT INSTALLED <input type="checkbox"/> Pitless adapter _____ inches above grade	
Shale (Blue-Hard)		110	120	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: TANK ft. 300 Direction S Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Strader Orla Co Inc 182 Business name _____ License No. _____ Address RT 1 Halton Kans Signed Orla Strader Date 11-6-75 Authorized representative	
18. Elevation: 1205'		19. Remarks: CONCRETE SLAB INSTALLED BY Jack Neef			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

T 9 S
R 6 E
Sec 6
1/4 1/4 1/4