

43

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

80 y sub-DIVISION, lot # 14

1. Location of well:	County Riley	Fraction SW SW 1/4 NW 1/4 NW 1/4	Section number 28	Township number T 10	Range number S 7	EW
2. Distance and direction from nearest town or city: 2.5 SW of			3. Owner of well: RON BELCHER			
Street address of well location if in city: MANHATTAN			R.R. or street: City, state, zip code: MANHATTAN			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 10 in. Completion date _____ Well depth 70 ft. 5-25-77		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
		From		To		9. Casing: Material PVC Height: 60 or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 2 1/2 in. RMP <input type="checkbox"/> PVC 9L Weight 250 lbs./ft. Dia. 5 in. to 70 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 258
						10. Screen: Manufacturer's name _____ Pumeco Type PVC Dia. 5 100 gauge 1020 Length 10 Set between 60 ft. and 70 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 20x60
						11. Static water level: _____ mo./day/yr. 30 ft. below land surface Date 5-25-77
						12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50 g.p.m.
						13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____
						14. Well head completion: CAP <input type="checkbox"/> Pitless adapter 29 inches above grade
						15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
						16. Nearest source of possible contamination: ft. 100 Direction E Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Stank Daly Co Inc 182 Business name _____ License No. _____ Address RT 1 Manhattan, KS Signed Don Adams Date 5-25-77 Authorized representative
18. Elevation: 1037		19. Remarks: OWNER TO INSTAL SLAB				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

10-2028
T
R
W
S
C
1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5